

62048715

VESSEL (A) : 2988261

DATE OF INSPECTION : 1994 OCT 05

Boiler and Pressure Vessel Safety

# Certificate of Inspection

HUSKY OIL OPERATIONS LTD.  
0205237 PRODUCTION DEPT.  
BOX 1008  
LLOYDMINSTER, SK  
S9V 0Z8

LOCATION: STOCK WAREHOUSE  
COMPANY CODE:  
DESCRIPTION: FIN EXCHANGER

PREFERRED RE-INSP. INTERVAL: .00 YRS  
CRN: K2766.2

MANUFACTURER: AIR-X-CHANGERS  
SERIAL # : 944411.4

YEAR BUILT: 1994  
CUBICAL CAPACITY: m3

HEATING SURFACE: 13.40 m2

PART	MAX.AUTHORIZED PRESSURE	MAX.TEMP/ MIN.TEMP	SAFETY VALVES ID/LOCATION	SET/CAPACITY	AT TEMP
------	-------------------------	--------------------	---------------------------	--------------	---------


FIN EXCHANGER	4516 kPa	148 C -28 C	SV1 SYSTEM	4378 kPa 130 M3M	
---------------	----------	----------------	---------------	---------------------	--

\*\*\* BOILER OR PRESSURE VESSEL NOT SUBJECT TO ANNUAL REGISTRATION FEES

OWNER INSTRUCTIONS/REMARKS:

NO FURTHER INSPECTION REQUIRED BY ALBERTA BOILER & PRESSURE VESSEL SAFETY  
OWNER TO VERIFY INTEGRITY OF VESSEL BY PERIODIC INSPECTION PROGRAM.

INSPECTOR: MALTAIS, DONALD D.

SIGNATURE: 

NOTE: REQUIREMENTS OF THE BOILERS AND PRESSURE VESSELS ACT AND THE REGULATIONS ISSUED THEREUNDER:

THE OWNER OR PERSON IN CHARGE SHALL REPORT ALL ACCIDENTS INVOLVING A BOILER, PRESSURE VESSEL OR PRESSURE PIPING SYSTEM TO THE DISTRICT INSPECTOR IMMEDIATELY AND SHALL SEND A FULL REPORT IN WRITING TO THE CHIEF INSPECTOR AS REQUIRED BY THE ACT. NO REPAIRS OR ALTERATIONS MAY BE MADE UNLESS AUTHORIZED BY AN INSPECTOR.