


SEPARATOR INSPECTION REPORT Page: 1 of 2

Radiography: RT-2 P.W.H.T. NO Position: VERTICAL Support: SKIRT -	INSPEC	TION S	ERVICES LTI) .		SE	PARA	IUR	CIII	PECII	ON R	EPUR	l	Page	e: 1 of 2
STATIC DATA	FACILITY:		TANGLEFL	AGS GA	S FIE	LD	DATE:	1	OVE	MBER 2, 2				05110	2GENp
A	AREA SUPER'	VISOF	2:		[DENNIS I	McKAGUE				COS	ST CENTR	E:	781	34
Company I.D. #: BC-169623 Manufacturer: G2048705 Notification Number: G2048705 Service S LTD. Serial Number: G831 Service S LTD. Serial Number: Serial Number: G832 Service S LTD. Serial Number: G832 Service S LTD. Service S L				Ballini											
Manufacturer: RJV GASFIELD SERVICES LTD. Serial Number: 6831					7 7 7 10									-	
Equip. Description: 2 PHASE VERTICAL SEPARATOR Location (LSD): 04-18-051-25W3							er: 60362 8	85				pany I.D. #:	BC-	169623	3
Vear Built: O7/2001 Vessel Class:															
Province Installed: SASKATCHEWAN			2 PHASE V	ERTICA							04-18	-051-25W	3		
MAWP:			-		Year				Vess	sel Class:			-		
Radiography: RT-2 P.W.H.T. NO Position: VERTICAL Support: SKIRT - Manway: NO Size: - mm Nozzie Rating: 300 # ANS External Coating: YES Insulated: NO NOzimeter: 508 mm Length: S/S 1524 mm Overall Length: - mm Location: - mm L									1	-				BC-16	9621
Manway	MAWP:												Capac	ity:	- m
Diameter: 508				N	0									-	
Internal Coating:	Manway:	NO	Size:		mm	Nozzle I	Rating: 3	00 #	ANSI	External	Coating	: YES	Insulat	ed:	NO
Material Thickness Corrosion Allowance	Diameter:	508	mm L	ength:	S/S	1524	4 m	nm O	verall	Length:		-	mm		
Material Thickness Corrosion Allowance	nternal Coatin	g: N	O Type:			5	Int	ernal			Typ	e:		-	
SA-106B	nspection Port	t: N	O Size #1	: - n	nm Loc	cation:		-		Size #2:	- n	nm Locatio	n:	-	
SA-106B			197	Mate	rial			7	hickn	ess		Cor	rosion	Allowa	nce
Top Head	Shell										mm				mr
Section Head SA-516-70							1 -7								mr
Product Description: NATURAL GAS Operating Pressure: 10 Kpa Operating Temperature: 5 °C PSV STATIC DATA Tag Number: Company I.D. #: Set Pressure: Capacity: Back Pressure: 40523 BC-169626 4965 Kpa 1944 SCFM 0 Kpa 1944 SCF		- 14 S		SA-51	6-70			1	1.88		mm		1.60		mr
Product Description: NATURAL GAS Operating Pressure: 10 Kpa Operating Temperature: 5 °C PSV STATIC DATA Tag Number: Serial Number: Company I.D. #: Set Pressure: Capacity: Back Pressure: - 40523 BC-169626 4965 Kpa 1944 SCFM O Kpa Manufacturer: Model # / Type: CRN: CODE STAMP Inlet Size: Rating: Outlet Size: Rating: WELLMARK W9501-RS800 - UV NB 25 mm - # 25 mm - Location of PSV: SIDE OF THE SEPARATOR 02/1998 Inspection Reason: SIDE OF THE SEPARATOR 02/1998 Inspection Test Plan#: - Inspection Type Used: VE, UT Last Inspection Date: - Next Inspection Type: VE, UT Last Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.		124		SA-10)5N			1	1.07		mm	==	1.60		mr
Product Description: NATURAL GAS Operating Pressure: 10 Kpa Operating Temperature: 5 °C PSV STATIC DATA Tag Number: Company I.D. #: Set Pressure: Capacity: Back Pressure - 40523 BC-169626 4965 Kpa 1944 SCFM 0 Kpa 1944 S	Outlet Nozzle			SA-10)5N		de la company	1	1.07		mm		1.60		mr
Next Inspection Date: 10 Kpa Operating Temperature: 5 Coperating Temperature: 5 Coperating Temperature: 5 Coperating Temperature: Coperating Temperature				Cata table	Zali.	P	PROCESS	DAT	A	N. Carlotta			The Holes		
PSV STATIC DATA Tag Number: Serial Number: Company I.D. #: Set Pressure: Capacity: Back Pressure: - 40523 BC-169626 4965 Kpa 1944 SCFM 0 Kpa Manufacturer: Model # / Type: CRN: CODE STAMP Inlet Size: Rating: Outlet Size:	Product Descri	iption:	NATURAL	GAS								Service	e: Swe	et	
Tag Number: Company I.D. #: Set Pressure: Capacity: Back Pressure:	Operating Pres	ssure:		10		Кра	Operatin	g Ter	nperat	ure:		5			°C
Hospection Reason: Code Inspection Inspection Type Used: VE, UT Set UNO. / C.C.# Code Inspection Date: Next Inspection Date: Next Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C Code Inspection; reschedule as indicated. Yes Partial inspection; do not reschedule. Next Inspection; reschedule. Next Inspection; do not			to into task tall	2 2 4 1		PS	SV STATI	C DA	TA					te-ijele	
Manufacturer: Model # / Type: CRN: CODE STAMP Inlet Size: Rating: Outlet Size: Rating: WELLMARK W9501-RS800 - UV NB 25 mm - #	Tag Numbe	r:	Serial	Number	:	Compa	any I.D. #:	: :	Set Pre	essure:	C	apacity:	Ba	ck Pr	essure:
WELLMARK W9501-RS800 - UV NB 25 mm - # 25 mm -			40	523		BC-									Kpa
Sommittee Continued Service Continued Se					GEL.	CRN:			E STA			Rating:		Size:	Rating
SIDE OF THE SEPARATOR INSPECTION DETAILS Inspection Reason: Code Inspection Inspection Type Required: VE, UT Inspection Test Plan#: - Inspection Type Used: VE, UT Last Inspection Date: - Next Inspection Type: VE, UT Next Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.	WELLMAF	RK	W9501-R	S800	111	-	2006	UV	N	IB 25	mm	- #			-
Inspection Reason: Code Inspection Inspection Type Required: VE, UT								7,					S		
Inspection Reason: Code Inspection Inspection Type Required: VE, UT Inspection Test Plan#: - Inspection Type Used: VE, UT Last Inspection Date: - Next Inspection Type: VE, UT Next Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C Next Inspection Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.				S	IDE OF									02/1	998
Inspection Test Plan#: - Inspection Type Used: VE, UT Last Inspection Date: - Next Inspection Type: VE, UT Next Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.	Edition Colonia	Lucia		A CONTRACTOR OF THE PARTY OF TH	1.							Water Bridge	THE PARTY		
Last Inspection Date: Next Inspection Type: VE, UT Next Inspection Due: Outstanding Repairs: VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.															
Next Inspection Due: 2010 Outstanding Repairs: NO RBI Category: A B C VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.											1 144	0 100 "			
VESSEL STATUS Integrity Status: Suitable for Continued Service Inventory Status: In Service In Service Integrity Status: Inte				10						17				-	<u> </u>
Integrity Status: Suitable for Continued Service Inventory Status: In Service This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.	Next Inspection	n Due:	20	10	Outst					_	IKB	Category:	IA I	B	
This IR completes a thorough inspection; reschedule as indicated. Yes Partial inspection; do not reschedule.	-1		itable for O		0					4 It	0	Jaskina.	4-40-		Par File
													-4	h a d d	
	inis ik compl	etes a	tnorougn i	nspection	on; res					s Partial	inspec	tion; do n	ot resc	nedul	9.
INSPECTION SUMMARY		NAME !				INSP	ECTION	SUMI	MARY		128 18-1				AND ROLL
	· ·		•	_						ns.					
						recomm	ended fit	for se	rvice.						
No notable defects were observed; the vessel is recommended fit for service.				at this tin	ne.										
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time.															
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time															
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time. No IDRs were issued at this time.															
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time No IDRs were issued at this time. There was no internal inspection performed at this time.	There was no	interna	al NDE perfo	rmed at	this tin	ne.									
-No notable defects were observed; the vessel is recommended fit for serviceThere are no recommendations at this timeThere are no repairs at this time -No IDRs were issued at this timeThere was no internal inspection performed at this time.								Can be							
-An inspection to verify the Vessel's integrity was done by UT and VE inspectionsNo notable defects were observed; the vessel is recommended fit for serviceThere are no recommendations at this timeThere are no repairs at this time -No IDRs were issued at this timeThere was no internal inspection performed at this timeThere was no internal NDE performed at this time.						REC	COMMEN	DATI	ONS			3000			
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time No IDRs were issued at this time. There was no internal inspection performed at this time.															
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time. No IDRs were issued at this time. There was no internal inspection performed at this time. There was no internal NDE performed at this time.							<u> </u>								
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time. No IDRs were issued at this time. There was no internal inspection performed at this time. There was no internal NDE performed at this time. RECOMMENDATIONS			Baki balanci		-18	REP	AIRS CO	MPLE	TED					E AND D	
No notable defects were observed; the vessel is recommended fit for service. There are no recommendations at this time. There are no repairs at this time No IDRs were issued at this time. There was no internal inspection performed at this time. There was no internal NDE performed at this time.															

INSPECTION OBSERVATIONS NON COMPLIANCES ISSUED INSPECTION DEFICIENCIES ISSUED EXTERNAL VISUAL INSPECTION The nameplate, instrumentation, piping and piping attachments are in fair condition. The vessel's ground connection is through the skid's ground rod. The vessel's profused with no notable coating defects. The skid piping is painted with no notable defects. The piping both up grading is B7 and 2H. The separator is welded to the skid floor. There is adequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a dequate access to the bottom head. There is a depart of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The inspections were performed by Silvertip Inspection Services Ltd. The inspections were performed by Silvertip Inspection Services Ltd. The inspection in a continuation of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The inspection is the UT reports for more detailed information. INTERNAL VISUAL INSPECTION INTERNAL NDE PRESSURE TESTS The inspection in advised above the been inspected in a containing the profuse of the UT values recorded are serviced and that the statements within this report are correct and represently dispection findings. External Inspector's Name: Inspector's Certification: Inspector's Name: Inspector's Certification: Inspector's Name: Inspector's Name: Inspector's Name: Inspector's Name: Inspector's Name: Inspector's Certification: Inspector's Name: Inspector's Name: Inspecto	The PSV is past due for servicing See NCR051102GENd. The nameplate, instrumentation, The vessel's ground connection is The vessel is painted with no note The skid piping is painted with no The piping bolt up grading is B7 at The separator is welded to the skid here is adequate access to the Infere are no apparent leaks in the The outside piping insulation clades.	piping and pipir is through the skable coating deformation and 2H. kid floor. bottom head. he system.	EXTERNAL VISION of the condition. e for servicing.	ICIENCIES JAL INSPEC	JED SSUED		#: IR051102GENp
INSPECTION DEFICIENCIES ISSUED EXTERNAL VISUAL INSPECTION The nameplate, instrumentation, piping and piping attachments are in fair condition, he vessel's ground connection is through the skid's ground rod. He vessel is painted with no notable coating defects. He skid piping is painted with no notable defects. He piping bolt up grading is B7 and 2H. He separator is welded to the skid floor. Here is adequate access to the bottom head. Here are no apparent leaks in the system. He outside piping insulation cladding is in fair condition. He vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. Here is the UT reports for more detailed information. INTERNAL VISUAL INSPECTION INTERNAL NDE PRESSURE TESTS Set Completed: - Test Pressure: Kpa Test Acceptable: - Test Report #: - INSPECTOR CERTIFICATION INTERNAL VISUAL INSPECTION INTERNAL NDE PRESSURE TESTS Set Completed: - Test Pressure: Kpa Test Acceptable: - Thest Report #: - INSPECTOR CERTIFICATION INTERNAL VISUAL INSPECTION INTERNAL NDE External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Only Normand Piston Report Scattification: Inspector's Signature: Date: Certification: Certifica	The nameplate, instrumentation, The vessel's ground connection is The vessel is painted with no note The skid piping is painted with no The piping bolt up grading is B7 at The separator is welded to the skill there is adequate access to the Infere are no apparent leaks in the The outside piping insulation clades.	piping and pipir is through the skable coating defects and 2H. kid floor. bottom head. he system.	EXTERNAL VISION DEF and attachments kid's ground rod fects. es.	JAL INSPEC	SSUED		
INSPECTION DEFICIENCIES ISSUED EXTERNAL VISUAL INSPECTION The nameplate, instrumentation, piping and piping attachments are in fair condition. The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable defects. The skid piping is painted with no notable defects. The piping both up grading is P3 and 2H. The separator is welded to the skid floor. There is adequate access to the bottom head. There are no apparent leaks in the system. The outside piping insulation cladding is in fair condition. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The services Ltd. Forms of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. For more detailed information. INTERNAL NDE PRESSURE TESTS Set Completed: - Test Pressure: - Kpa Test Acceptable: - Test Report #: - INSPECTION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE Inspector's Alme: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Leave "As Is": Change to: PS	The nameplate, instrumentation, The vessel's ground connection is The vessel is painted with no note The skid piping is painted with no The piping bolt up grading is B7 at The separator is welded to the skid here is adequate access to the Interes are no apparent leaks in the outside piping insulation clades.	piping and pipir is through the skable coating defects and 2H. kid floor. bottom head. he system.	ng attachments kid's ground rod fects. es.	JAL INSPEC are in fair co	TION		
EXTERNAL VISUAL INSPECTION The nameplate, instrumentation, piping and piping attachments are in fair condition. The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable defects. The skid piping is painted with no notable defects. The piping bott up grading is B7 and 2H. The separator is welded to the skid floor. There is adequate access to the bottom head. There are no apparent leaks in the system. The outside piping insulation cladding is in fair condition. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. Some of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. The inspection of the UT reports for more detailed information. INTERNAL VISUAL INSPECTION INTERNAL NDE PRESSURE TESTS ast Completed: Test Pressure: Kap Test Acceptable: Test Report #: Test Pressure: NSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in a for dance with the assigned task list and that the statements within this report are correct and represent the present of the present that the statements within this report are correct and represent the present of the	The vessel's ground connection is the vessel is painted with no noted. The skid piping is painted with no he piping bolt up grading is B7 at the separator is welded to the skill here is adequate access to the later are no apparent leaks in the outside piping insulation clades.	piping and piping and the skable coating deformable defects and 2H. kid floor. bottom head. he system.	ng attachments kid's ground rod fects. es.	JAL INSPEC are in fair co	TION		
The nameplate, instrumentation, piping and piping attachments are in fair condition. The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable coating defects. The skid piping is painted with no notable defects. The piping bolt up grading is B7 and 2H. The separator is welded to the skid floor. There is adequate access to the bottom head. There are no apparent leaks in the system. The outside piping insulation cladding is in fair condition. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. The separator is welded to the skid floor. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. The service	The vessel's ground connection is the vessel is painted with no noted. The skid piping is painted with no he piping bolt up grading is B7 at the separator is welded to the skill here is adequate access to the later are no apparent leaks in the outside piping insulation clades.	piping and pipir is through the sk able coating det o notable defects and 2H. kid floor. bottom head. ne system. dding is in fair co	ng attachments kid's ground rod fects. ss. ondition. e for servicing.	are in fair co			
The nameplate, instrumentation, piping and piping attachments are in fair condition. The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable coating defects. The skid piping is painted with no notable defects. The piping bolt up grading is B7 and 2H. The separator is welded to the skid floor. There is adequate access to the bottom head. There are no apparent leaks in the system. The outside piping insulation cladding is in fair condition. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. The separator is welded to the skid floor. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE IT inspections were performed by Silvertip Inspection Services Ltd. The service	The vessel's ground connection is the vessel is painted with no notation in the skid piping is painted with no he piping bolt up grading is B7 at the separator is welded to the skid here is adequate access to the lifthere are no apparent leaks in the outside piping insulation clad	piping and pipir is through the sk able coating det o notable defects and 2H. kid floor. bottom head. ne system. dding is in fair co	ng attachments kid's ground rod fects. ss. ondition. e for servicing.	are in fair co			
The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable coating defects. The piping is painted with no notable defects. The piping is welded to the skid floor. The vessel is welded to the skid floor. The vessel is welded to the skid floor. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE STERNAL NDE To inspections were performed by Silvertip Inspection Services Ltd. Some of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. See the UT reports for more detailed information. INTERNAL VISUAL INSPECTION INTERNAL NDE PRESURE TESTS Set Completed: Test Pressure: Kpa Test Acceptable: Test Report # - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representing inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Exercise Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Pyears State Test Test Test Test Test Test Test Te	The vessel's ground connection is the vessel is painted with no noted. The skid piping is painted with no he piping bolt up grading is B7 at the separator is welded to the skill here is adequate access to the later are no apparent leaks in the outside piping insulation clades.	is through the skitched coating deformation of the skitched coating deformation and 2H. It is a skitched coating in the skitched coating is in fair coating in the skitched coating in fair coating is in fair coating in the skitched coating in the skitched coating is in fair coating in the skitched coating in the skitched coating is in fair coating in the skitched coating in the skitched coating in the skitched coating in the skitched coating the s	kid's ground rod fects. ss. ondition. e for servicing.		ndition.		
The vessel's ground connection is through the skid's ground rod. The vessel is painted with no notable coating defects. The piping is painted with no notable defects. The piping is welded to the skid floor. The vessel is welded to the skid floor. The vessel is welded to the skid floor. The vessel is protected by a PSV that is past due for servicing. EXTERNAL NDE STERNAL NDE To inspections were performed by Silvertip Inspection Services Ltd. Some of the UT values recorded are below nominal; however, they are still within corrosion allowance limits. See the UT reports for more detailed information. INTERNAL VISUAL INSPECTION INTERNAL NDE PRESURE TESTS Set Completed: Test Pressure: Kpa Test Acceptable: Test Report # - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representing inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Exercise Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Pyears State Test Test Test Test Test Test Test Te	The vessel's ground connection is the vessel is painted with no noted. The skid piping is painted with no he piping bolt up grading is B7 at the separator is welded to the skill here is adequate access to the later are no apparent leaks in the outside piping insulation clades.	is through the skitched coating deformation of the skitched coating deformation and 2H. It is a skitched coating in the skitched coating is in fair coating in the skitched coating in fair coating is in fair coating in the skitched coating in the skitched coating is in fair coating in the skitched coating in the skitched coating is in fair coating in the skitched coating in the skitched coating in the skitched coating in the skitched coating the s	kid's ground rod fects. ss. ondition. e for servicing.		ndition.		
INTERNAL VISUAL INSPECTION I, the undersigned, certify that the equipment stated above has been inspected in a condance with the assigned task list and that the statements within this report are correct and representing inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As I			EXTER	NAL NDE			
INTERNAL VISUAL INSPECTION INTERNAL VISUAL INSPECTION INTERNAL NDE PRESSURE TESTS Set Completed: - Test Pressure: - Kpa Test Acceptable: - Test Report #: - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representing inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Ease Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": C							
PRESSURE TESTS est Completed: - Test Pressure: - Kpa Test Acceptable: - Test Report #: - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and represent in inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date:		ailed information	1.			wance limit	s.
PRESSURE TESTS est Completed: - Test Pressure: - Kpa Test Acceptable: - Test Report #: - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representation inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date:			THE RIVIE VIOL	AL IIIOI LO	11011		
PRESSURE TESTS est Completed: - Test Pressure: - Kpa Test Acceptable: - Test Report #: - INSPECTOR CERTIFICATION I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representation inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date:							
I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representative inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date:		at room to be	INTERN	IAL NDE	The state of the s		
Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years Years Years Years							
Inspector certification I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representative inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date:			PRESSU	RE TESTS		And the second	
I, the undersigned, certify that the equipment stated above has been inspected in accordance with the assigned task list and that the statements within this report are correct and representative inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years Years Years Years	est Completed: - Test F	Pressure:				Report #:	-
and that the statements within this report are correct and representary inspection findings. External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE November 2, 200 Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK Essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years Years Years Years						711 11	
External Inspector's Name: Inspector's Certification: Inspector's Signature: Date: Guy Normand API 510, 653, ABSA PESL, NACE Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years 5 Years Years 7 Years 7 Years							
CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION							
Internal Inspector's Name: Inspector's Certification: Inspector's Signature: Date: CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years 5 Years Years 5 Years Onte: Date: Date: PSV Inspection Interval: Leave "As Is": Change to: Years Years Years					mapada b oig	mature.	
CHIEF OR LEAD INSPECTOR'S ACCEPTANCE AND SCHEDULE CONFIRMATION Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years 5 Years Years				•	Inspector's Sig	nature.	
Inspector's Name: Inspector's Certification: Inspector's Signature: Date: RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years 5 Years Years 5 Years Inspector's Signature: Date: Aug On auchuk O 5 - // - 09 Change to: PSV Inspection Interval: Leave "As Is": Change to Years Years	-	Поре	-		-\	,	
RAY TRACHUK essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: 5 Years Years 5 Years Years		LEAD INSPECT	TOR'S ACCEPT	TANCE AND	The state of the s		N
essel Inspection Interval: Leave "As Is": Change to: PSV Inspection Interval: Leave "As Is": Change to: Years 5 Years Years		Inspe	ector's Certificati	on:			Date:
5 Years Years 5 Years Years		Comment of the					
		eave "As Is":				Leave "	
ffice Use Only: Report Entered to SEQA Database by: Date: Date: Date: Date: Date:		4 amon 30 M to 4 at 4 5 5 5		(1	Years		Yea
Static Data Verified by:			atabase by:	Ko	rom		5/11/15 N

INSPECTION SERV	ICES LTD.			01 1143	DI L	SHORK	CLIO	17.1		PAC	3E 1 OF 1	
FACILITY:	TANGLEFLAGS	S GAS FIELD		DATE:		NOVEMBE	R 2, 2005	5	REPORT #:	IR051	IR051102GENp	
AREA SUPERVISOR:			DENNIS	McKAGUE					COST CENTE	RE: 7	8134	
	MARILLONE OF LUIS	Commence of the U.S.	Total Lating	STATIC DA	TA		la Je	1000				
Alberta Reg. #:	475057		CRN	H-6948.2				National	Board #:		•	
Equipment Number:	62048705	Notificatio	n Number:	6036285				Company	/ I.D. #:	BC-169623		
Manufacturer:	RJV GASFIELD SER\	VICES LTD.				Serial Number	:	6831		- 1	-	
Equip. Description:	2 PHASE VERTICAL	SEPARATOR			L	Location (LSD)):	04-18-05	1-25W3			
Equipment Tag #:		Year Bui	ilt:	07/2001		Vessel Cl	lass:					
Province Installed:	SASKATCHEWAN			egistration #:				Skid / Bu	ilding #:	BC-	169621	
MAWP: 4969	5 Kpa @	38 °C	MDMT:	-29		°C Code	1:	Α	SME U	Capacity:	- m3	
Diameter: 508	mm Length	: S/S	1524	mm	n Ove	erall Length:				mm		
		Material				Thickness			C	orrosion Allowa	nce	
Shell		SA-106B		-	12	2.70		mm		1.60	mm	
Top Head		SA-516-70			11	.88		mm		1.60	mm	
Bottom Head		SA-516-70			11	.88		mm		1.60	mm	
Product Description:	NATURAL GAS					-			Service:	Sweet		
		as a hear	and the ball of	PSV STATIC I	DATA	1. April 12 8 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		in diamen				
Tag Number:	Serial Numl	ber:	Compa			Set Pressure:		Capacity:		Back	Pressure:	
-	40523		BC-	-169626		4965	Kpa	1944	4 SCFN	0 1	Kpa	
Manufacturer:	Model # / Type:		CRN:		COD	E STAMP	Inlet	Size:	Rating:	Outlet Size:	Rating:	
WELLMARK	W9501-RS800		-		UV	NB	25	mm	- #	25 mm	-	
		L	ocation of	PSV:						Servi	ce Date:	
		SIDE	OF THE SEI	PARATOR						02	/1998	



LOOKING NORTH

BC-169623	NOMINAL	UT READING	BELOW NOMINAL		The second second second	
Manager Control		2005	when the same of the same			
LOC 001	0.436	0.439				
LOC 002	0.468	0.490			11 5 5	
LOC 003	0.468	0.520				7 7 2 2 7 7
LOC 004	0.500	0.518				
LOC 005	0.436	0.437				
LOC 006	0.500	0.512				4
LOC 007	0.500	0.510				
LOC 008	0.500	0.513				
LOC 009	0.468	0.529		- 1		
LOC 010	0.468	0.494				
LOC 011	0.436	0.429	0.007			