

L7-03-003-00552

TANK INSPECTION REPORT

SR. Operator: Red Simon

Approver Code: 22-8000474

Requisitioned by: Mike L

Work Order: 1001798

LOCATION 16-31-51-22wsm DATE 2-June-11 TANK TYPE Production
MFG GLM YEAR 2005 S/N G-05-241-SB CAP 1000 BBL AFE/CC 25413
FLOOR THK. 1/4 SHELL THK. 1/4 x 3/16 ROOF THK. 3/16
SAP# 166116499

EXTERNAL SURFACE


INSULATION:	<u>GOOD</u>	FAIR	POOR
CLADDING:	<u>GOOD</u>	FAIR	POOR <u>N/A</u>
BASE/LAND SCAPING:	<u>GOOD</u>	FAIR	POOR
LINER/CONTAINMENT:	<u>YES</u>	NO	
GROUND CABLE:	<u>YES</u>	NO	
LADDER/STAIRS:	<u>GOOD</u>	FAIR	POOR
PLATFORM	<u>GOOD</u>	FAIR	POOR
PIPING ALIGNMENT:	<u>GOOD</u>	FAIR	POOR
SHELL:	<u>GOOD</u>	FAIR	POOR
ENVIROVAULT:	<u>YES</u>	NO	CONDITION: <u>good</u>
ROOF:	<u>GOOD</u>	FAIR	POOR
PAINT:	<u>GOOD</u>	FAIR	POOR

FIRETUBE:

INTERNAL CONDITION: GOOD BOWED NO OVALLED NO FLANGE (LEAKING) Yes NO
REGULATOR: Yes No RATING: unable to see due to Radiator Type Burner

INTERNAL SURFACE:

FLOOR CONDITION:	<u>GOOD</u>	FAIR	POOR
SHELL CONDITION:	<u>GOOD</u>	FAIR	POOR
ROOF CONDITION:	<u>GOOD</u>	FAIR	POOR
FIRETUBE:	<u>GOOD</u>	FAIR	POOR
PIPING/NOZZLE CONDITION:	<u>GOOD</u>	FAIR	POOR
BACKWELDING REQ:	YES <u>NO</u>	WHERE	
ANODES:	Yes <u>No</u>	Total <u>BLOCK</u>	CYLINDRICAL <u>CONSUMED</u> %
COATING:	Yes <u>No</u>	GOOD <u>FAIR</u> <u>POOR</u>	TYPE:



NOTES:

replace Both Stinger Nozzles
2" load pump riser support
remade guide wires
Stinger gauges

54AS

CONTACT:

Well Head / Sales Tax 6

Type of Inspection: Visual and UT	Job/P.O.#: WO#1001798	IRISNDT #: 149635	Date: 2-Jun-11
Test Technique: Thickness 0 deg	Client: Husky Energy Operations		
Equipment: DMS II, Flashlight, Grinder	Location: Westhazel, Sask		
	Item Inspected: 2-1000 bbl tank		
	Code: API 653		

Appr: Rod Simons
Appr# 2Z-8000474



Requisitioner: Mike L.
PO# 8400326695

UT and visual examination was carried out on (2) 1000 bbl tank at the following location:

Production tank
S/N G05-241-S8

Sales Tank
S/N G05-241-S13
LSD: 16-31-51-22W3M

See the following pages for results

Unit#: 569	Kilometers: 100	Consumables:	Interpretation by:	SNT-TC-1A
In: 1100	Out: 1300	Min	Tristan Sommerfeld	C.G.S.B. API 653
In:	Out:		(Print)	(Level)
	Hrs: 2.0			C.G.S.B. # 38910
Personnel:			Client Representative:	
Tristan Sommerfeld			(Print) Ray Trachuk	
Janesta Legge			(Sign) 	
			I am in full agreement with report contents	