



NOTES

1. ALL CABLES ARE TO BE ARMoured AND BOTTOM ENTRY.

2. REFER TO DETAIL 023 IN DWG. 18319-EN-BM-0004 FOR THE LIST OF MATERIALS.

3. CONDUIT SIZE TO BE DETERMINED BY CONTRACTOR.

ENGINEERING COMPANY PERMIT STAMP

REGISTERED PROFESSIONAL ENGINEER STAMP

WHEN SIGNED & DATED, THE ENGINEERING SEAL & PERMIT AFFIXED ABOVE WILL APPLY TO THE CLOUDED AREAS FOR THE CURRENT REVISION ONLY.

6		
5		
4		
3		
2		
1		

REF	DRAWING NUMBER	DRAWING TITLE
REFERENCE DRAWINGS		
1	2017/11/17	AS BUILT FOR MOC 16508564

REV	DATE	DESCRIPTION	BY	CHK	ENG	APR
REVISION HISTORY						

Husky Oil Operations Limited

ANSELL 02-20-050-18W5 COMPRESSOR STN

TITLE

GENERATOR BUILDING (X-520)

ANALOG/24VDC CONTROL JUNCTION BOX LAYOUT (JBDC-160)

SURFACE LOCATION

02-20-050-18W5

ALTERNATE DWG NUMBER

HUSKY DWG NUMBER

VENDOR DWG NUMBER

AMU/FLOC NUMBER

DCN NO

REV NO

1

SCALE

NTS

PROJECT NO

MOC 16508564