

SEP.

CERTIFIED BY: SPECTRUM PROCESS SYSTEMS

www.spectrumprocess.ca

CALGARY, ALBERTA, CAN.



M.A.W.P. 265

P.S.I. AT 150 °F

M.A.E.W.P. 15

P.S.I. AT 150 °F

M.D.M.T. -49

°F AT 265 P.S.I.

SERIAL # 14-05110-32 YEAR BUILT 2014

W

CRN V6435.2

TAG # V-326

R.T.- 2

SH./HD. MATERIAL: SA-333-6 SA-516-70N

SH. W.T. 3/8"

HD. W.T. MIN. .3125"

C.A. .0625"

TEST: 398 PSI

PROV. REG.

Ⓐ 643886

NB

ASME

UV

ANDERSON GREENWOOD CROSBY

2014-12

SIZE
STYLE

1.5 6 3 JOS E 14-J

SET PRESS.

1792.6 KPA

CDTP

1702.968 KPA

SER
NO

C14104794

BP

89.632

TC

CAP

71.96 M3/MIN

OVER-
PRESS.

10 %

ASSEMBLED BY PENTAIR VALVES & CONTROLS

PSV-326

EDN

CRN

0615494.52

CROSBY
CHINA
14870-6

NB

ASME

UV

ANDERSON GREENWOOD CROSBY

2014-12

SIZE
STYLE

1.5 G 3 JOS E 14 J

SET PRESS.

1792.6 KPA

CDTP

1702.968 KPA

SER
NO

C14104794

BP

89.632

TC

CAP

71.96 M3/MIN

OVER-
PRESS.

10 %

ASSEMBLED BY PENTAIR VALVES & CONTROLS

PSV-326

EDM

CRN

0615494.52



FARRIS ENGINEERING
DIV. OF CURTISS - WRIGHT F.C.C.
BRECKSVILLE, OHIO USA

TYPE 07CA33-M20/S4 11/14

SIZE AND ORIFICE 1 C 1

SET PRESS 1782 KPAG

BACK PRESS 0 KPAG

HOLD OFF TEST PRESS 1792 KPAG

CAPACITY AT 10% OVER PRESS 9.3 M3/MIN

SIN 82772-2-KE 2323873-2

TAG PSV-326B

CRN DGT1969.5C

ASM

UV

NB

ASM BY FARRIS PRESS. MGMT. CANADA

26906X12

FARRIS ENGINEERING
DIV. OF CURTISS - WRIGHT F.C.C.
BRECKSVILLE, OHIO USA

TYPE 27CA33-M20/S4 11/14

SIZE AND ORIFICE 1 C 1

SET PRESS 1792 KPAG

BACK PRESS 0 KPAG

COLD DIFF. TEST PRESS 1792 KPAG


CAPACITY AT 10% OVER PRESS 9.3 M3/MIN

S/N 827712-2-KE 2323873-2

TAG FSV-326B

CRN 0611969.5C

ASM BY FARRIS PRESS. MGMT. CANADA



UV



28005X12

