

2 - flash vessel (V-327)

2 - d: UIA.

A 646898

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
 As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Spectrum Process Systems Inc. 285175 Kleysen Way, Rocky View, Alberta. T1X 0K1 Canada
 (Name and address of manufacturer)
2. Manufactured for Husky Energy. 707-8th Avenue SW. Box 6525, Station "D" Calgary, Alberta T2P 3G7
 (Name and address of manufacturer)
3. Location of installation LSD: 02-20-050-18 W5M
 (Name and address)
4. Type Vertical Flash Vessel 14-05110-33 W7305.21 V-14-05110-33-001 R.0 - 2014
 (Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing numbers) (National Board number) (Year built)
5. ASME Code, Section VIII, Division 1 2013 Ed. N/A N/A
 (Edition and Addenda, if applicable (date)) (Code Case numbers) (Special service per UG 120(d))
6. Shell SA-106B 3/8" .0625" 1'-7 1/4" 5'-0"
 (Material spec. number, grade) (Nominal thickness) (Corr. allow) (Inner diameter) (Length overall)

Body Flange on Shell												
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thik)	Washer Material
-	-	-	-	-	-	-	-	-	-	-	-	-

7. Seams Seamless N/A 100% N/A N/A Typel Spot 70% 1
 (Long, welded, dbl, singl, lap, butt) (R.T. (spot or full)) (Eff., %) (H.T. temp.) (Time, hr) (Girth (welded, dbl, singl, lap, butt)) (R.T. (spot or full)) (Eff., %) (No. of courses)
8. Heads: (a) Material SA-516-70N (b) Material SA-516-70N
 (Spec. no., grade) (Spec. no., grade)

	Location (Top, Bottom, End)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side Pressure (Convex or Concave)
(a)	Top Head	.3125"	.0625"	-	-	2:1	-	-	-	Concave
(b)	Bot Head	.3125"	.0625"	-	-	2:1	-	-	-	Concave

Body Flange on Head												
No.	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thik)	Washer Material
(a)	-	-	-	-	-	-	-	-	-	-	-	-
(b)												

9. MAWP 270 PSIG 15 PSIG at max. temp. 150 F 150 F
 (Internal) (External) (Internal) (External)
- Min. design metal temp. -20 F at 270 PSIG Hydro., pneu., or comb. test pressure 405 PSIG
- Proof test N/A

10. Nozzles, inspection, and safety valve opening:

Purpose (Inlet, Outlet, Drain etc.)	No.	Diameter or Size	Type	Material		Nozzle thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
LSHH/LC/LSLL/Insp.	3	4"	RFWN/CL150	SA-106B	SA-105N	.337"	.0625"	Integral	UW16.1(c)	Typel	Shell
Gas outlet/Insp.	1	3"	RFWN/CL150	SA-106B	SA-105N	.300"	.0625"	Integral	UW16.1(c)	Typel	Head
Gly In/Skim out/Skim LG/TL	5	2"	RFWN/CL150	SA-106B	SA-105N	.344"	.0625"	Integral	UW16.1(c)	Typel	Shell
Gly LG/Gly out/PSV/Gas in	5	2"	RFWN/CL150	SA-106B	SA-105N	.344"	.0625"	Integral	UW16.1(c)	Typel	Shell
Drain	1	2"	RFWN/CL150	SA-106B	SA-105N	.344"	.0625"	Integral	UW16.1(c)	Typel	Head

11. Supports: Skirt Yes Lugs N/A Legs N/A Other N/A Attached Welded to Bot. Head
 (Yes or No) (Number) (Number) (Describe) (where and how)
12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A
 (Name of part, item number Manufacturer's name and identifying stamp)
- 20 F All Materials Exempt from impact test per UG-20(f)(1-5). Tag # V-327
- Volume: 11.9 Cu.ft (.34 Cu.M) PSV Installed by other as per UG-125 Construction DWG. NO: V-14-05110-33-001 R.0

FORM U-1A (Back)

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 21,356 expires July 21, 2016

Date December 15, 2014 Co. name Spectrum Process Systems Inc.

(Manufacturer)

Signed

Hassan

(Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Spectrum Process Systems Inc. 285175 Kleysen Way, Rocky View, Alberta. T1X 0K1 Canada
I, the undersigned holding valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by ABSA, Calgary, Alberta, Canada

have inspected the component described in this Manufacturer's Data Report on Dec 17/14, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury, property damage or a loss of any kind arising from or connected with this inspection.

Date Dec 17/14 Signed

(Authorized Inspector)

Commissions

NB 110357 AB-C1

(National Board (incl. endorsements))

9-b: NIP + CRN

FLASH VESSEL

CERTIFIED BY: SPECTRUM PROCESS SYSTEMS

www.spectrumprocess.ca

CALGARY, ALBERTA, CAN.

M.A.W.P. 270 P.S.I. AT 150 °F

M.A.E.W.P. 15 P.S.I. AT 150 °F

M.D.M.T. -20 °F AT 270 P.S.I.

SERIAL # 14-05110-33 YEAR BUILT 2014

CRN W 7305.21 TAG # V-327

SH./HD. MATERIAL: SA-106B/ SA-516-70N

SH. W.T. 3/8" HD. W.T. MIN. .3125"

C.A. .0625" TEST: 405 PSI

PROV. REG.

646898

November 20, 2014

Attention: Joe Laing
SPECTRUM PROCESS SYSTEMS INC
285175 KLEYSEN WAY SE
ROCKYVIEW COUNTY, AB

The design submission, tracking number 2014-06646, originally received on August 15, 2014 was surveyed and accepted for registration as follows:

CRN : W7305.2

Accepted on: November 20, 2014

Reg Type: New Design

Drawing No. : V-14-05110-33-001 Rev 0 As Noted

Description	MAWP	Design Temperature	MDMT
Internal Pressure	1862kPa	66 °C	-29 °C
External Pressure	103kPa	66 °C	-29 °C

The registration is conditional on your compliance with the following notes:


This design is accepted for registration based on the understanding that:

- In accordance to UG-99 (d), we are issuing the following note: the requirement of UG-99 does not specify an upper limit for hydrostatic test pressure. However, if the hydrostatic test pressure is allowed to exceed, either intentionally or accidentally, the value determined to a degree that the vessel is subjected to visible permanent distortion, the Inspector shall reserve the right to reject the vessel.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 or fax (780) 437-7787 or e-mail su@absa.ca.

Sincerely,



SU, YI, E.I.T.

9-C'. Travel sheet.

TRAVEL SHEET

A.I. REVIEW <i>Tough</i>		REVIEW DATE: <i>12 August 2014</i>	
VES. TYPE: Flash Vessel	SERIAL # 14-05110-33	JOB #:	Final Dstn.
DESCRIPTION	FAB DWG# V-14-05110-33-001 R.0	CRN	TASK COMPLETION DATES AND INSPECTORS INITIALS
20" OD60" S/S X3/8" WT	CRN# V-14-05110-33-001 R.0		
ITEM	TAG#: V-327	Q.C.I.	DATE
1) Calculations in file		<i>How</i>	Aug 11, 14
2) Release of approved Construction Dwgs		<i>How</i>	Aug 11, 14
3) Weld /Mat'l Impact Test	EXEMPT to -20 F	<i>How</i>	8/6/14
4) Heat Numbers recorded on Travel Sheet (backside)		<i>How</i>	9/10/14
5) M.T.R.'s checked		<i>How</i>	9/10/14
6) Weld Procedures Checked		<i>How</i>	8/21/14
7) Shell and Head Thicknesses Measured		<i>How</i>	9/6/14
8) Nozzles and Fittings Fitted		<i>How</i>	
9) Nozzle orientation Checked		<i>How</i>	
10) Noz/Flg/TOL/CPLG rating checked		<i>How</i>	
11) Noz/Flg/TOL/CPLG Mat'l Spec./Grade checked		<i>How</i>	
Material Inspection		<i>How</i>	9/10/14
13.1) Internals- Final or Progress	13) Final Internal Inspection	<i>How</i>	8/28/14
Top Head	14) Shell and Head Fitted	<i>How</i>	9/10/14
Top Sec	15) Weld size checked	<i>How</i>	9/10/14
Mid-Top Sec	16) Welder I.D. & Welder Qualification checked	<i>How</i>	8/28/14
Mid-Mid Sec	17) ATTACHMENTS	<i>How</i>	9/10/14
Mid-Btm Sec	18) Attachments I.D.	<i>How</i>	9/10/14
Btm Sec	19) Radiography	<i>How</i>	9/7/14
Btm Head	20) Other NDT	<i>How</i>	9/10/14
	21) Serial # Hard Stamped by NP Brkt.	<i>How</i>	8/28/14
	22) Full Dia. Break Flgs. Stamped as per UG-116(L)		
	23) Btm Head H1# trans. to Straight Flg.	<i>How</i>	9/10/14
	24) Final External Insp. Prior to PWHT	PWHT - NO	
	25) Stress Chart checked		
	26) Final External with Hydro	<i>How</i>	8/28/14
	27) HYDROTESTING/ VESSEL Water temp. min. 40°F	405 psi Ga#	520/F44
	HEC/HECO(Non-B & PV Code)	kPa	psi Ga#
	28) Nameplate Stamped	<i>How</i>	9/10/14
	29) Accepted CRN drawing	<i>How</i>	9/10/14
	30) Manuf. Data Report	<i>How</i>	9/10/14
	31) Partial Data Reports		
	32) Nameplate Installed	<i>How</i>	9/10/14
	33) NCR Cleared		

* DENOTES AN A.I. INSPECTION POINT

** DENOTES AN A.I. HOLD POINT

AUTHORIZED INSPECTOR SHALL BE GIVEN TRAVEL SHEET PRIOR TO CONSTRUCTION SO THAT HE CAN DESIGNATE INSP. AND HOLD POINTS

[illegible]

9-d: Hydro.

6 AM

7

8

9

10


11

NOON

1

2

3



PRINTED IN U.S.A.

CALIBRATION REPORT



#9, 1815 - 27 Avenue N.E.
Calgary, Alberta T2E 7E1
Phone (403) 291-3535
Fax (403) 291-3585

CALGARY
MEDICINE HAT
WAINWRIGHT

IM 57305

DATE: Oct 27/14. DATE LAST CALIBRATED: RENTAL.
OPERATING COMPANY: SPECTRUM PROCESS SYSTEMS P.O. # _____
LOCATION: SHOP ☐ WELL ☐ BATTERY ☐ PLANT AREA: Calgary
DEVICE TYPE: Barton SERIAL NUMBER: 545028 JOB NUMBER: 5110

DIFFERENTIAL RANGE: — ☐ W.C. ☐ kPa STATIC RANGE: 1000 ☒ psig ☐ psia ☐ kPa ☐ kPaA
TEMPERATURE RANGE: 0-150 ☒ °F ☐ °C

METER READINGS

DIFFERENTIAL STATIC TEMPERATURE
Before _____
After _____

ZERO READINGS: Found _____ Left _____

Differential: _____

Static: _____

METER RUN SIZE;

Upstream: _____ ☐ in. ☐ m.m.

Downstream: _____ ☐ in. ☐ m.m.

ORIFICE FITTING;

Make: _____ ☐ Slow ☐ Quick

☐ FLANGE ☐ Condition ☐ O.K.

☐

ORIFICE PLATE; Size: _____

CONDITION: ☐ O.K. ☐ Rejected

SPECIFIC GAS GRAVITY: _____

Sample Point: ☐ Meter Run ☐ Separator ☐ Treater

MANIFOLD; ☒ Over ☐ Under

Properly in Service: ☐ Yes ☒ No

Dampening: ☒ O.K. ☐ Adjusted

Valves: ☒ O.K. ☐ Leaking ☐ Seized ☐ Repaired

DRIFLOW PENS; ☐ O.K. ☒ Adjusted

Tension: ☒ O.K. ☐ Adjusted

Inking: ☒ O.K. ☐ Adjusted

CLOCK ROTATION; ☐ 7 DAYS ☐ 24 HOURS

☒ ELECTRONIC

Comments:

Parts:

INSPECT METER
CLEAN & INSPECT LINKAGE
CHECK ARC & PENS.
CHECK CALIBRATION AS
PER ATTACHED.

Calibration Standard S/N 10489 Traceable to NIST

Standard File No. 836/8366608

Approved By: [Signature]

Tech.: [Signature]

Form: 04166004

Labour

Vehicle

SUB TOTAL