

Husky Energy

PRESSURE VESSEL INSPECTION REPORT

PAGE : 1 of 3

FACILITY	Ansell Field	DATE	May 4, 2008	REPORT #	IR080504JNA
----------	--------------	------	-------------	----------	-------------

VESSEL STATIC DATA

Prov. Insp. #	A 0416384 ✓	CRN	K2360.21	Equip Tag #	002168 ✓
Equipment Location (LSD)	12-23-051-19 W5M	Serial #	PE 4869 ✓	Vessel Class	-
Equipment Description	Vertical Separator	Year Built	1997 ✓	MAWP	1436 psi
Manufacturer	Penfabco Ltd.	KPag / psig	@ 100°F	MDMT	-20°F
CODE : UM ☐ U ☒ U2 ☐	RT : 1 ☐ 2 ☒ 3 ☐ 4 ☐	°C / °F	PWHT : YES ☐ NO ☒		
Diameter	16"	Length	(S/S) mm/in	OAL	mm/in
Shell Mat'l		Thickness	mm	Corr Allowance	0 mm/in
Head Mat'l		Thickness	mm	Corr Allowance	0 mm/in
Nozzle Mat'l		Thickness	mm/in	Corr Allowance	mm/in
Internal Coating : YES ☐ NO ☒	Internal Clad : YES ☐ NO ☒	Capacity	N/A m ³		
Manway : YES ☐ NO ☒	Inspection Port : YES ☐ NO ☒	Skirt ☒ Legs ☐ Saddle ☐			
Nozzle Rating	600 lb ANSI	Painted : YES ☒ NO ☐	Insulated : YES ☐ NO ☒		

PROCESS DATA

Product Description	Sweet Gas	Sweet ☒ Sour ☐ PPM:	
Operating Pressure	550 psi	KPag / psig	Operating Temperature 60°F

PSV STATIC DATA

Tag / Serial No.	Location	Size Inlet	Size Outlet	Set Pressure	Capacity SCFM / Lbs/Hr / GPM	Manufacturer	Model / Type	Service Date
66030	Pipe	1"	1"	1436 psi	2918 SCFM	Mercer	9117D5 117145	07/06

INSPECTION HISTORY

RBI Category	A ☐ B ☐ C ☐ D ☐	Last Inspection Date	W.O. #
Inspection Task List #		Inspection Type	Inspection Reason Integrity Inspection SM
Inspection Techniques Required		Next Inspection Type	Due Date
VE ☐ VI ☐ RT ☐ UT ☐ MT ☐ PT ☐ TT ☐		Outstanding Repairs	

INSPECTION SUMMARY

An external inspection was performed to verify the vessels integrity.
No concerns were found and the vessel is considered acceptable for continued service.

RECOMMENDATIONS

- Cut a new 4" inspection hole in the east side of the vessel skirting to permit UT inspection on the bottom head in the future.
- Tighten minor oil leak in the 1" threaded piping.

REPAIRS COMPLETED

Object Name	Cause	Damage	Repair Activity
None			

VESSEL STATUS

Integrity Status	☒ Suitable for Continued Service	☐ Immediate Repairs Required	☐ Replace
Inventory Status	☒ In service Fully Utilized	☐ Future Repairs Required	☐ Scrap
		☐ Idle	☐ Surplus
This IR completes a thorough inspection. Reschedule as indicated		☒ Partial IR only. Do not reschedule	☐

FACILITY	Ansell Field	DATE	May 4, 2008	REPORT #	IR080504JNA
----------	--------------	------	-------------	----------	-------------

INSPECTION OBSERVATIONS**NONCOMPLIANCES OR INSPECTION DEFICIENCIES ISSUED**

-None at time of inspection.

EXTERNAL VISUAL INSPECTION

The vessel is painted and is in good condition with no notable corrosion being found.
The nameplate, bolting and external attachments are in good condition.
The piping is in fair condition, there are minor leaks in many of the threaded pipe unions.
The vessel is protected with a PSV that is attached and in good condition.
The gauges are clear and in good condition.
The vessel appears to be secure and level.
The overall condition of this vessel is good.

-Cut a new 4" inspection hole in the east side of the vessel skirting to permit UT inspection on the bottom head in the future.

EXTERNAL NDE EXAMINATION

-An external ultrasonic corrosion survey was completed. No relevant indications were noted at the time of inspection. For more details see formal UT report by Hunt Inspection - Project C2780

INTERNAL VISUAL INSPECTION

-There was no internal Visual at time of inspection.

INTERNAL NDE EXAMINATION

-There was no internal NDE at time of inspection.


PRESSURE TEST

Test Completed	☐ Yes ☐ No	Test Acceptable	☐ Yes ☐ No	Test Report #
----------------	--	-----------------	--	---------------

INSPECTOR CERTIFICATION

I, the undersigned certify that the above equipment has been inspected in accordance with the assigned task list and that statements within this report are correct and represent inspection findings

Inspectors Name Joel Norman

Inspector's Signature 


Inspection Company Hunt Inspection Ltd.

Date

May 04, 2008

LEAD INSPECTOR'S ACCEPTANCE & SCHEDULE CONFIRMATION

Lead Inspector Bob Marchak

Signature 

Date 10-10-2008

Vessel Inspection Interval 5 Years

Leave "as-is" ☐

Change to

PSV Inspection Interval 5 Years

Leave "as-is" ☐

Change to

Office Use Only Report Entered to SEQA Database by
Static Data Verified by

Date
Date

FACILITY	Ansell Field	DATE	May 4, 2008	REPORT #	IR080504JNA
----------	--------------	------	-------------	----------	-------------

Data Plate Photo





66048163

ITEM:

VERTICAL SEPARATOR

A 0416384



HUNT
INSPECTION LTD.
STETTLER, AB (403) 742-4868
LACOMBE, AB (403) 782-7855
BROOKS, AB (403) 501-8029
GRANDE PRAIRIE, AB (866) 422-9732

TECHNICIAN:

JOEL NORMAN
SNT LEVEL III
CGSB 48.9712
LEVEL III # 6951

DATE: **05/04/08**DWG # **87**CLIENT: **HUSKY ENERGY**LSD: **12-23-051-19-W5M**

INSPECTOR: BOB MARCHAK

LOCATION: ANSELL FIELD

DISTRICT UNIT: FH-FW

BLDG/SKID: -

PROCESS: SWEET

CODE: ASME SEC VIII DIV 1

SPECIFICATION: AS PER ASME SE 797

TECHNIQUE: UT-1-1, REV. 1

METHOD: UT CONTINUOUS / A SCAN

SURFACE COND: PAINTED

SURFACE TEMP: AMBIENT

VESSEL INFORMATIONVESSEL #: **A 0416384**

CRN #: K2360.2

SERIAL #: PE 4869

MANUFACTURER: PENFABCO LTD.

DATE BUILT: 1997

CLIENT ID / TAG: BC 002168

M.A.W.P.: 1436 PSI

M.A.W.T.: 100 °F

JOINT EFFICIENCY/RT: RT 2

STRESS RELIEVED: NO

INSULATED: NO

MANWAY: NO

VESSEL SPECIFICATIONS

	OD	NOMINAL	MATERIAL	CA
VESSEL HEAD	16"	.750"	SA-516-70	0"
VESSEL SHELL	16"	.844"	SA-106-B	0"
BOOT HEAD	-	-	-	-
BOOT SHELL	-	-	-	-

COMMENTS:

NO ACCESS TO BOTTOM HEAD & DRAIN BELOW SKIRTING

PROJECT:

C2780



ULTRASONIC CORROSION SURVEY

Survey Name: HUSKY ENERGY

LSD: 12-23-051-19W5 Dwg: 87 Vessel Number: A0416384
District Unit: FH-FW Vessel Name: VERTICAL SEPARATOR
Location: ANSELL FIELD Year Built: 1997
Skid: - Tag Number: BC002168
CRN: K2360.2

Survey Date: 5/04/08
Inspector: BOB MARCHAK
Process: SWEET
Project #: C2780
Manufacturer: PENFABCO LTD.
Serial Number: PE4869
Shell MAWP PSI: 1436 MAWT F: 100
Tube MAWP PSI: 0 MAWT F: 0
Vessel CA: 0.0000

Band	Description			Readings						Year	Avg Inches	Min Inches	Nominal	CA	TMIN	Recommended Next Inspection	Recommended Retirement Date
				1	2	3	4	5	6								
87-05	Top	Head	Baseline	0.736	0.731	0.731	0.732	0.731	0.733	2008	0.732	0.731	0.7500	0.0000	0.5998	2009	2028
Shape	Ellipsoidal	Shell Side	Previous										Comments-->				
OD	16		Current	0.736	0.731	0.731	0.732	0.731	0.733	2008	0.732	0.731	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				Caution				
Material	SA 516 - 70								LT Loss MPY		0.000						
87-10	Upper	Shell	Baseline	0.830	0.830	0.833	0.835	0.838	0.837	2008	0.834	0.830	0.8440	0.0000	0.7287	2009	2028
Shape	Cylindrical	Shell Side	Previous										Comments-->				
OD	16		Current	0.830	0.830	0.833	0.835	0.838	0.837	2008	0.834	0.830	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				Caution				
Material	SA 106 - B								LT Loss MPY		0.000						
87-15	Upper	Shell	Baseline	0.850	0.844	0.844	0.844	0.850	0.851	2008	0.847	0.844	0.8440	0.0000	0.7287	2009	2028
Shape	Cylindrical	Shell Side	Previous										Comments-->				
OD	16		Current	0.850	0.844	0.844	0.844	0.850	0.851	2008	0.847	0.844	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				OK				
Material	SA 106 - B								LT Loss MPY		0.000						
87-20	Mid	Shell	Baseline	0.808	0.807	0.813	0.816	0.817	0.815	2008	0.813	0.807	0.8440	0.0000	0.7287	2009	2028
Shape	Cylindrical	Shell Side	Previous										Comments-->				
OD	16		Current	0.808	0.807	0.813	0.816	0.817	0.815	2008	0.813	0.807	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				Caution				
Material	SA 106 - B								LT Loss MPY		0.000						



ULTRASONIC CORROSION SURVEY

Survey Name: HUSKY ENERGY

LSD: 12-23-051-19W5 Dwg: 87
District Unit: FH-FW
Location: ANSELL FIELD
Skid: -

Vessel Number: A0416384
Vessel Name: VERTICAL SEPARATOR
Year Built: 1997
Tag Number: BC002168
CRN: K2360.2

Manufacturer: PENFABCO LTD.
Serial Number: PE4869
Shell MAWP PSI: 1436 MAWT F: 100
Tube MAWP PSI: 0 MAWT F: 0
Vessel CA: 0.0000

Survey Date: 5/04/08
Inspector: BOB MARCHAK
Process: SWEET
Project #: C2780

Band	Description			Readings						Year	Avg Inches	Min Inches	Nominal	CA	TMIN	Recommended Next Inspection	Recommended Retirement Date
				1	2	3	4	5	6								
87-25	Lower	Shell	Baseline	0.810	0.810	0.815	0.818	0.825	0.829	2008	0.818	0.810	0.8440	0.0000	0.7287	2009	2028
Shape	Cylindrical	Shell Side	Previous										Comments-->				
OD	16		Current	0.810	0.810	0.815	0.818	0.825	0.829	2008	0.818	0.810	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				Caution				
Material	SA 106 - B								LT Loss MPY		0.000						
87-30	Bottom	Head	Baseline	0.788	0.794	0.792	0.790	0.789	0.788	2008	0.790	0.788	0.7500	0.0000	0.5998	2009	2028
Shape	Ellipsoidal	Shell Side	Previous										Comments-->				
OD	16		Current	0.788	0.794	0.792	0.790	0.789	0.788	2008	0.790	0.788	NOMINAL & MATERIAL ASSUMED				
Spec.	VIII Div 1								ST Loss MPY				OK				
Material	SA 516 - 70								LT Loss MPY		0.000						
87-35		Piping	Baseline	0.319	0.310	0.315	0.316	0.321	0.325	2008	0.318	0.310	0.3000	0.0375	0.1213	2009	2028
Shape	90° Elbow	Shell Side	Previous										Comments-->				
OD	3.5		Current	0.319	0.310	0.315	0.316	0.321	0.325	2008	0.318	0.310					
Spec.	B31.3								ST Loss MPY				OK				
Material	A 234 - WPB								LT Loss MPY		0.000						
87-40		Piping	Baseline	0.319	0.310	0.307	0.308	0.315	0.319	2008	0.313	0.307	0.3000	0.0375	0.1213	2009	2028
Shape	90° Elbow	Shell Side	Previous										Comments-->				
OD	3.5		Current	0.319	0.310	0.307	0.308	0.315	0.319	2008	0.313	0.307					
Spec.	B31.3								ST Loss MPY				OK				
Material	A 234 - WPB								LT Loss MPY		0.000						



ULTRASONIC CORROSION SURVEY

Survey Name: HUSKY ENERGY

LSD: 12-23-051-19W5 Dwg: 87

District Unit: FH-FW

Location: ANSELL FIELD

Skid: -

Vessel Number: A0416384

Vessel Name: VERTICAL SEPARATOR

Year Built: 1997

Tag Number: BC002168

CRN: K2360.2

Manufacturer: PENFABCO LTD.

Serial Number: PE4869

Shell MAWP PSI: 1436 MAWT F: 100

Tube MAWP PSI: 0 MAWT F: 0

Vessel CA: 0.0000

Survey Date: 5/04/08

Inspector: BOB MARCHAK

Process: SWEET


Project #: C2780

Band	Description			Readings						Year	Avg Inches	Min Inches	Nominal	CA	TMIN	Recommended Next Inspection	Recommended Retirement Date
				1	2	3	4	5	6								
87-45	Piping	Baseline		0.312	0.306	0.308	0.306	0.310	0.312	2008	0.309	0.306	0.3000	0.0375	0.1213	2009	2028
Shape	90° Elbow	Shell Side	Previous										Comments-->				
OD	3.5		Current	0.312	0.306	0.308	0.306	0.310	0.312	2008	0.309	0.306					
Spec.	B31.3												ST Loss MPY				
Material	A 234 - WPB												LT Loss MPY 0.000				
													OK				
87-50	Piping	Baseline		0.303	0.278	0.278	0.277	0.290	0.303	2008	0.288	0.277	0.3000	0.0375	0.1213	2009	2028
Shape	90° Elbow	Shell Side	Previous										Comments-->				
OD	3.5		Current	0.303	0.278	0.278	0.277	0.290	0.303	2008	0.288	0.277					
Spec.	B31.3												ST Loss MPY				
Material	A 234 - WPB												LT Loss MPY 0.000				
													OK				

④ ▲

VERTICAL SEPARATOR - PIPING

A 0416384



STETTLER, AB (403) 742-4868
LACOMBE, AB (403) 782-7855
BROOKS, AB (403) 501-8029
GRANDE PRAIRIE, AB (866) 422-9732

TECHNICIAN:

JOEL NORMAN
SNT LEVEL III
CGSB 48.9712
LEVEL III # 6951

DATE: **05/04/08**

DWG # 87A

CLIENT: HUSKY ENERGY

LSD: 12-23-051-19-W5M

INSPECTOR : BOB MARCHAK

LOCATION :	ANSELL FIELD
-------------------	--------------

DISTRICT UNIT : FH-FW

BLDG/SKID: -

PROCESS:	SWEET
-----------------	-------

CODE:	ASME B31.3
--------------	------------

SPECIFICATION:	AS PER ASME SE 797
-----------------------	--------------------

TECHNIQUE: UT-1-1, REV. 1

METHOD: UT CONTINUOUS / A SCAN

SURFACE COND:	PAINTED
----------------------	---------

SURFACE TEMP: AMBIENT


PIPING INFORMATION

[illegible]

COMMENTS:

PROJECT:

C2780

VESSEL UT LOCATIONS

Name:	Vertical Separator	MAWP:	1436psi
A:	0416384	Des. Temp.:	100°F
S/N:	PE4869	Head Material:	SA-516-70
CRN:	K2360.2	Head Thick:	0.694"
LSD:	12-23-51-19 W5M	Shell Material:	SA-106-B
Location:	Ansel Field	Shell Thick:	0.844"
Corr. Allow.:	Nil	Date Built:	1997
Size:	14.32"ID x 7'6"	Manufacturer:	Penfabco Ltd.

Note:

- Location 1 on top head.
- Location 4 above bottom head.
- Location 5 - 3" elbow east of vessel.
- Location 6 - 3" elbow above top head
- No access to bottom head.

Corrosion Monitoring Equipment ID Analysis Report

Report For: Husky Energy
 Presented By: Alliance Engineering & Inspection Ltd.
 Address: 333-50 Avenue SE, Calgary, AB T2G 2B3
 Telephone: (403) 255-5100 Fax: (403) 255-5171 Web www.aeilttd.com

Report Date: 11/11/2003

(Report in Inches, Corrosion Rates in MPY)
 Analysis: Statistical/Straight Line

Unit: HUSKY
 Eq/Circ ID: 0416384
 Eq Type:
 Class:
 RBI:
 Design Code: S8/D1

Flange Rating: 0 lb/in²
 Design Pressure: 1436 lb/in²
 Design Temperature: 100 °F

Description: VERTICAL SEPARATOR
 TAG # N/A

Summary: Group Name:

Insp. Due Date = 09/09/2008

Pred. Ret. Date = 11/01/2032

Group Description: .

RCR = 0.1 MPY

Rem. Life (from last survey 09/10/2003) = 29.1 yrs

0 C.A. Status: No

Total Caution TMLs = 0

TML No	Location Description	Ctn TML	First Survey Thick Nt	First Date	Previous Survey Thick Nt	Previous Date	Last Survey Thick Nt	Last Date	Shrt Term Rate	Long Term Rate	Best Rate	Max Hist CR	Retirement Thickness	Rep TML CR	TML Retirement Date	TML Inspection Date
1.01	TOP HEAD	N *	0.694 NM	04/15/1997		N/A	0.741	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2032	09/09/2008
1.02	TOP HEAD	N *	0.694 NM	04/15/1997		N/A	0.737	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2030	09/09/2008
1.03	TOP HEAD	N *	0.694 NM	04/15/1997		N/A	0.737	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2030	09/09/2008
1.04	TOP HEAD	N *	0.694 NM	04/15/1997		N/A	0.750	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/09/2036	09/09/2008
1.05	TOP HEAD	N	0.694 NM	04/15/1997		N/A	0.803	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2063	09/09/2008
2.01	SHELL	N	0.844 NM	04/15/1997		N/A	0.873	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	09/10/2070	09/09/2008
2.02	SHELL	N	0.844 NM	04/15/1997		N/A	0.852	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2060	09/09/2008
2.03	SHELL	N	0.844 NM	04/15/1997		N/A	0.852	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2060	09/09/2008
2.04	SHELL	N	0.844 NM	04/15/1997		N/A	0.845	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	09/09/2056	09/09/2008
2.05	SHELL	N	0.844 NM	04/15/1997		N/A	0.846	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2057	09/09/2008
2.06	SHELL	N	0.844 NM	04/15/1997		N/A	0.844	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2056	09/09/2008
2.07	SHELL	N	0.844 NM	04/15/1997		N/A	0.842	09/10/2003	N/A	0.3	N/A	0.3	0.739 U	2.0	03/11/2055	09/09/2008
2.08	SHELL	N	0.844 NM	04/15/1997		N/A	0.844	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2056	09/09/2008
2.09	SHELL	N	0.844 NM	04/15/1997		N/A	0.844	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2056	09/09/2008
2.10	SHELL	N	0.844 NM	04/15/1997		N/A	0.843	09/10/2003	N/A	0.2	N/A	0.2	0.739 U	2.0	09/10/2055	09/09/2008
2.11	SHELL	N	0.844 NM	04/15/1997		N/A	0.846	09/10/2003	N/A	0	N/A	0	0.739 U	2.0	03/11/2057	09/09/2008
2.12	SHELL	N	0.844 NM	04/15/1997		N/A	0.842	09/10/2003	N/A	0.3	N/A	0.3	0.739 U	2.0	03/11/2055	09/09/2008
3.01	SHELL	N	0.844 NM	04/15/1997		N/A	0.834	09/10/2003	N/A	1.6	N/A	1.6	0.739 U	2.0	03/11/2051	09/09/2008
3.02	SHELL	N	0.844 NM	04/15/1997		N/A	0.830	09/10/2003	N/A	2.2	N/A	2.2	0.739 U	2.2	01/20/2045	09/09/2008
3.03	SHELL	N	0.844 NM	04/15/1997		N/A	0.828	09/10/2003	N/A	2.5	N/A	2.5	0.739 U	2.5	04/17/2039	09/09/2008

Report For: Husky Energy
 Presented By: Alliance Engineering & Inspection Ltd.
 Address: 333-50 Avenue SE, Calgary, AB T2G 2B3
 Telephone: (403) 255-5100 Fax: (403) 255-5171 Web www.aeilttd.com

Report Date: 11/11/2003

(Report in Inches, Corrosion Rates in MPY)
 Analysis: Statistical/Straight Line

Unit: HUSKY
 Eq/Circ ID: 0416384
 Eq Type:
 Class:
 RBI:
 Design Code: S8/D1

Flange Rating: 0 lb/in²
 Design Pressure: 1436 lb/in²
 Design Temperature: 100 °F

Description: VERTICAL SEPARATOR
 TAG # N/A

Summary: Group Name:
 Insp. Due Date = 09/09/2008
 Pred. Ret. Date = 11/01/2032

Group Description:
 RCR = 0.1 MPY
 Rem. Life (from last survey 09/10/2003) = 29.1 yrs

0 C.A. Status: No
 Total Caution TMLs = 0

TML No	Location Description	Ctn TML	First Survey Thick Nt	First Date	Previous Survey Thick Nt	Previous Date	Last Survey Thick Nt	Last Date	Shrt Term Rate	Long Term Rate	Best Rate	Max Hist CR	Retirement Thickness	Rep TML CR	TML Retirement Date	TML Inspection Date
3.04	SHELL	N	0.844 NM	04/15/1997		N/A	0.829	09/10/2003	N/A	2.3	N/A	2.3	0.739 U	2.3	10/27/2042	09/09/2008
3.05	SHELL	N *	0.844 NM	04/15/1997		N/A	0.821	09/10/2003	N/A	3.6	N/A	3.6	0.739 U	3.6	06/21/2026	09/09/2008
3.06	SHELL	N *	0.844 NM	04/15/1997		N/A	0.820	09/10/2003	N/A	3.7	N/A	3.7	0.739 U	3.7	08/01/2025	09/09/2008
3.07	SHELL	N *	0.844 NM	04/15/1997		N/A	0.826	09/10/2003	N/A	2.8	N/A	2.8	0.739 U	2.8	10/06/2034	09/09/2008
3.08	SHELL	N *	0.844 NM	04/15/1997		N/A	0.823	09/10/2003	N/A	3.3	N/A	3.3	0.739 U	3.3	02/22/2029	09/09/2008
3.09	SHELL	N *	0.844 NM	04/15/1997		N/A	0.827	09/10/2003	N/A	2.7	N/A	2.7	0.739 U	2.7	04/13/2036	09/09/2008
3.10	SHELL	N	0.844 NM	04/15/1997		N/A	0.828	09/10/2003	N/A	2.5	N/A	2.5	0.739 U	2.5	04/17/2039	09/09/2008
3.11	SHELL	N *	0.844 NM	04/15/1997		N/A	0.827	09/10/2003	N/A	2.7	N/A	2.7	0.739 U	2.7	04/13/2036	09/09/2008
3.12	SHELL	N	0.844 NM	04/15/1997		N/A	0.828	09/10/2003	N/A	2.5	N/A	2.5	0.739 U	2.5	04/17/2039	09/09/2008
4.01	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.796	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2059	09/09/2008
4.02	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.799	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2061	09/09/2008
4.03	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.837	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2080	09/09/2008
4.04	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.835	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2079	09/09/2008
4.05	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.804	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2063	09/09/2008
4.06	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.801	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2062	09/09/2008
4.07	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.804	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2063	09/09/2008
4.08	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.804	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2063	09/09/2008
4.09	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.807	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2065	09/09/2008
4.10	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.808	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2065	09/09/2008
4.11	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.801	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	03/11/2062	09/09/2008
4.12	BOTTOM HEAD	N	0.694 NM	04/15/1997		N/A	0.804	09/10/2003	N/A	0	N/A	0	0.684 U	2.0	09/10/2063	09/09/2008

Corrosion Monitoring E ac ID Analysis Report

Report For: Husky Energy
 Presented By: Alliance Engineering & Inspection Ltd.
 Address: 333-50 Avenue SE, Calgary, AB T2G 2B3
 Telephone: (403) 255-5100 Fax: (403) 255-5171 Web www.aeilttd.com

Report Date: 11/11/2003

(Report in Inches, Corrosion Rates in MPY)

Analysis: Statistical/Straight Line

Unit: HUSKY
 Eq/Circ ID: 0416384
 Eq Type:
 Class:
 RBI:
 Design Code: S8/D1

Flange Rating: 0 lb/in²
 Design Pressure: 1436 lb/in²
 Design Temperature: 100 °F

Description: VERTICAL SEPARATOR
 TAG # N/A

Summary: Group Name:

Insp. Due Date = 09/09/2008

Pred. Ret. Date = 11/01/2032

Group Description:

RCR = 0.1 MPY

Rem. Life (from last survey 09/10/2003) = 29.1 yrs

0 C.A. Status: No

Total Caution TMLs = 0

TML No	Location Description	Ctn TML	First Survey Thick Nt	First Date	Previous Survey Thick Nt	Previous Date	Last Survey Thick Nt	Last Date	Shrt Term Rate	Long Term Rate	Best Rate	Max Hist CR	Retirement Thickness	Rep TML CR	TML Retirement Date	TML Inspection Date
5.01	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.352	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	03/11/2048	09/09/2008
5.02	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.338	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	03/11/2041	09/09/2008
5.03	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.333	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	09/10/2038	09/09/2008
5.04	3" ELBOW	N *	0.300 NM	04/15/1997		N/A	0.325	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	09/10/2034	09/09/2008
5.05	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.338	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	03/11/2041	09/09/2008
6.01	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.335	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	09/10/2039	09/09/2008
6.02	3" ELBOW	N *	0.300 NM	04/15/1997		N/A	0.329	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	09/09/2036	09/09/2008
6.03	3" ELBOW	N *	0.300 NM	04/15/1997		N/A	0.331	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	09/10/2037	09/09/2008
6.04	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.344	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	03/11/2044	09/09/2008
6.05	3" ELBOW	N	0.300 NM	04/15/1997		N/A	0.350	09/10/2003	N/A	0	N/A	0	0.263 U	2.0	03/11/2047	09/09/2008

Report For: Husky Energy
Presented By: Alliance Engineering & Inspection Ltd.
Address: 333-50 Avenue SE, Calgary, AB T2G 2B3
Telephone: (403) 255-5100 Fax: (403) 255-5171 Web www.aeilt.com

Report Date: 11/11/2003

(Report in Inches, Corrosion Rates in MPY)
Analysis: Statistical/Straight Line

Unit: HUSKY
Eq/Circ ID: 0416384
Design Code: S8/D1
Eq Type:
Class:
RBI:

Flange Rating: 0 lb/in²
Design Pressure: 1436 lb/in²
Design Temperature: 100 °F

Description: VERTICAL SEPARATOR
TAG # N/A

TML Corrosion Rates are each the Maximum of:

(A) -- Calculated Corrosion Rates x 1.00	:	Varies
(B) -- Default Corrosion Rate	:	2.0 MPY

Representative Corrosion Rate is the Maximum of:

(A) -- Average Corrosion Rate x 1.10	:	Not Used.
(B) -- Average Max 25.0% of TMLs, Min of 2	:	Not Used.
(C) -- Formula Corrosion Rate (Sigma = 1.28)	:	Not Used.
(D) -- Default Corrosion Rate	:	0.1 MPY

Representative Corrosion Rate = 0.1 MPY

TML thickness readings have not been compensated for high Temperatures.
TML thickness readings have not been compensated for growths.

TML Life calculations are based on the maximum of the Rep. TML CR and the RCR using Short
Term and Long Term Corrosion Rates.

Nominal thickness is used for TML corrosion rate calculations with less than 3 surveys.

Minimum time between inspections required for corrosion rate calculation is 6 months.

TML Inspection Interval is:

(A) -- Minimum(TML Life / 2.00, 5.0 years)

Eq/Circ ID Last Survey Date is based on the LAST of the last 0% of TML survey dates (Min 1).

Eq/Circ ID Estimated life = 29.1 years from the most recent survey date.
(Estimated Life based on the ave of the earliest 25% (Min 1) TML retirement dates.)

Predicted Eq/Circ ID Retirement date is 11/01/2032

Recommended Eq/Circ Internal Inspection Date is 09/09/2008
Internal Inspection Interval is the minimum(Remaining life / 2.0, 5.0 years).

Caution TML Logic: TML Corrosion Rate > 15.0 MPY .OR. TML Remaining Life < 1.00 Years.
There are 0 Caution TMLs in this Eq/Circ ID.

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

446324

1. Manufactured and certified by Penfabco Ltd. 5720 - 103A Street Edmonton, Alberta T6H 2J5
(Name and address of manufacturer)

2. Manufactured for Jiro Manufacturing Ltd. P.O. Box 1886 Stettler, Alberta T0C 2L0
(Name and address of purchaser)

3. Location of installation Stock Item
(Name and address)

4. Type Vertical PF 4869 K2360.21 PE-3213 Rev. 1 N/A 1997
(Material, or part, name) (Mfg's serial No.) (ICRN) (Drawing No.) (Natl. Std. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1995
Year

to 1995 N/A N/A
Address (Date) Code Case Num. Special Services per UG-120(d)

6. Shell: SA-106-B .844" Nil 14.32" 7'6" s/s
Matl. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft. & in.) Length (overall) (ft. & in.)

7. Seams: Smls N/A 100% N/A N/A Type 1 Full UW11(a)5(b) 1
Long. (Welded, Del., Sml., Lap, Butt) R.T. (Spot or Full) EN. (X) H.T. Temp. (°F) Time (hr) Girth (Welded, Del., Sml., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

8. Heads: (a) Matl. SA-516-70N (Spec. No., Grade) (b) Matl. SA-516-70N (Spec. No., Grade)

	Location (Top, Bottom, End)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Corrosion Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	Top	.694"	Nil	N/A	N/A	2:1	N/A	N/A	N/A	Concave
(b)	Bottom	.694"	Nil	N/A	N/A	2:1	N/A	N/A	N/A	Concave

If removable, bolts used (describe other fastenings) None
(Matl., Spec. No., Gr., Size, No.)

9. MAWP 1436 psi at max. temp. 100 °F
 Min. design metal temp. -20 °F at 1436 psi. Hydro., pneu., or comb. test pressure 2154 psi.

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Location
Inlet	1	3" 600#	BEWN	SA-105N/SA-106-B	Sch 160	N/A	Welded	Shell
Outlet	1	3" 600#	BEWN	SA-105N/SA-106-B	Sch 160	N/A	Welded	Top Head
Drain	1	2" 3000#	Colg	SA-105N/SA-106-B	Sch 160	N/A	Welded	Botm Head
Dump/Insp	1	2" 3000#	Colg	SA-105N	N/A	N/A	Welded	Shell

11. Supports: Skirt Yes Lugs No Legs No Other No Attached Welded to Botm Head
(Yes or no) (No) (No) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

Ultimate Owner: Jiro Manufacturing Ltd. (Name of part, item number, Mfg's name and identifying marks)
P.O. Box 1886 Stettler, Alberta Impact Tests Not Required Per UG-20(f)1-5
T0C 2L0 Volume: .26m³ Vertical 3-Phase Separator
Continued on U-4 Supplementary Sheet

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 14,383 expires 12-28 95.
 Date Apr 15/97 Co. name Penfabco Ltd. Signed M. Baya
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Penfabco Ltd. at Edmonton, Alberta
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Alberta and employed by Alberta Boilers Safety Association
 have inspected the component described in this Manufacturer's Data Report on April 15, 1997, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date April 15/97 Signed [Signature] Commissions Alberta 5
(Inspector) (Natl. Board rules and regulations, State, Pro and No.)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

[illegible]

Certificate of Authorization: Type U No. 14,323 Expires 12-28, 19 93

Date Apr 15/97 Name Penfabco Ltd. (Manufacturer) Signed M. Babin (Authorized Signatory)

Date April 15/97 Name W. Simpson (Authorized Distributor) Commission Alberta (Not valid without endorsement of State, Province and No.)

(12/91) This form (EEO118) may be obtained from the ASME Order Dept., 22 Llewellyn Drive, Box 2300, Fairfield, NJ 07007-2300 **REPRINT 9/93**

Husky Energy

PRESSURE VESSEL INSPECTION REPORT

#6023064 CT

66048163

PAGE: 1 of 2

FACILITY	Ansell Gas Plant Field	DATE	AUGUST 19, 2003	REPORT #	030819-DD-0
----------	------------------------	------	-----------------	----------	-------------

VESSEL STATIC DATA									
Prov. Insp. # 416384			CRN K 2360-21			Equip Tag #			
Equipment Location (LSD) 12-23-51-19W5			Serial # PE 4869						
Equipment Description 3 PHASE SEPARATOR			Vessel Class						
Manufacturer PENFARCO LTD			Year Built 1997						
MAWP 1436 KPag (psig) @ 100 °C/°F			MDMT -20 °C/°F						
CODE: UM ☐ U ☒ U2 ☐			RT: 1 ☐ 2 ☒ 3 ☐ 4 ☐			PWHT: YES ☐ NO ☒			
Diameter 16" Mm/in		Length		(T/T) Mm/in		OAL Mm/in		Vertical ☒ Horizontal ☐	
Shell Mat'l		Thickness		Mm/in		Corr Allowance		Mm/in	
Head Mat'l		Thickness		Mm/in		Corr Allowance		Mm/in	
Nozzle Mat'l		Thickness		Mm/in		Corr Allowance		Mm/in	
Internal Coating: YES ☐ NO ☒			Internal Clad: YES ☐ NO ☒			Capacity m ³			
Manway: YES ☐ NO ☒			Inspection Port: YES ☒ NO ☐			Skirt ☒ Legs ☐ Saddle ☐			
Nozzle Rating		lb ANSI		Painted: YES ☒ NO ☐		Insulated: YES ☐ NO ☒			

PROCESS DATA	
Product Description SOLUTION GAS	Sweet ☒ Sour ☐ PPM:
Operating Pressure 420 KPag (psig)	Operating Temperature 52 °C/°F

PSV STATIC DATA								
Tag / Serial No.	Location	Size Inlet	Size Outlet	Set Pressure	Capacity SCFM / Lbs/Hr / GPM	Manufacturer	Model / Type	Service Date
66030	OUTLET PIPING	1"	1"	1436	2918	MERLER		2003

INSPECTION HISTORY									
RBI Category A ☐ B ☐ C ☐ D ☐			Last Inspection Date			W.O. # 6023534			
Inspection Task List #			Inspection Type VE, UT			Inspection Reason INTEGRITY			
Inspection Techniques Required			Next Inspection Type VE, UT			Due Date 2008			
VE	VI	RT	UT	MT	PT	PT	TT	Outstanding Repairs	

INSPECTION SUMMARY	
VISUAL AND UT INSPECTIONS DID NOT REVEAL ANY DEFECTS AT THIS TIME.	

RECOMMENDATIONS	

REPAIRS COMPLETED			
Object Name	Cause	Damage	Repair Activity

VESSEL STATUS			
Integrity Status ☒ Suitable for Continued Service		☐ Immediate Repairs Required	
		☐ Future Repairs Required	
Inventory Status ☒ In service Fully Utilized		☐ Replace	
		☐ Scrap	
This IR completes a thorough inspection. Reschedule as indicated		☒ Partial IR only. Do not reschedule ☐	

PRESSURE VESSEL INSPECTION REPORT

PAGE : 2 of 2

FACILITY Ansell Gas Plant Field	DATE AUGUST 19, 2003	REPORT # 030819-DD-0
---	--------------------------------	--------------------------------

INSPECTION OBSERVATIONS**NONCOMPLIANCES OR INSPECTION DEFICIENCIES ISSUED****EXTERNAL VISUAL INSPECTION**

VESSEL IS BOLTED TO SKID.
MINOR OXIDIZING ON SHELL AND NOZZLES. PAINTED SURFACES ARE ACCEPTABLE.
PIPING IS SECURE AND PROPERLY SUPPORTED.
SIGHT GLASSES ARE IN GOOD WORKING CONDITION.

EXTERNAL NDE EXAMINATION

UT CARRIED OUT BY ALLIANCE ENG. NO SIGNIFICANT FINDINGS.

INTERNAL VISUAL INSPECTION**INTERNAL NDE EXAMINATION****PRESSURE TEST**

Test Completed ☐ Yes ☐ No	Test Acceptable ☐ Yes ☐ No	Test Report #
---	--	---------------

INSPECTOR CERTIFICATION

I, the undersigned certify that the above equipment has been inspected in accordance with the assigned task list and that statements within this report are correct and represent inspection findings


Inspectors Name DOUG DAVEY	Inspector's Signature 
Inspection Company ALLIANCE ENG. + INSP.	Date Nov 10/03

LEAD INSPECTOR'S ACCEPTANCE & SCHEDULE CONFIRMATION


Lead Inspector	Signature	Date
Vessel Inspection Interval 5	Leave "as-is" ☐	Change to
PSV Inspection Interval 5	Leave "as-is" ☐	Change to

Office Use Only Report Entered to SEQA Database by
Static Data Verified by

Date
Date



12-23-51-19w5 Separator



Name plate