

RJV GASFIELD SERVICES

4901- Bruce Road VEGREVILLE, ALBERTA T9C-1C3
PHONE # - 780 - 632-7774 FAX # - 780 - 632-6820

HYDRO TEST REPORT

SKID IDENTIFICATION NO.:

15198

RJV JOB NO.:

11-4868

TEST PRESSURE:

2160 PSI.

CUSTOMER:

HUSKY

TEMPERATURE:

AMBIENT

DATE OF TEST

OCT 28/2011

DURATION OF TEST:

1 HOUR

TEST FLUID:

WATER

CHARTED / WITNESSED

DESIGN PRESSURE:

1440 PSI

PIPING ONLY/ ASSEMBLED UNIT

PRESSURE GAUGE NO.:

43 + # 44

DATE LAST CALIBRATED:

JAN 18/2011

STATEMENT OF COMPLIANCE

I/ We the undersigned, declare that the described pressure piping system has been subjected to a Hyrotesting Procedure in accordance with the ASME Code, and find that it complies in all respects with the regulations for construction, installation, testing and inspection, and in this to be acceptable as to the specification of the said codes.

HYDROTEST PERFORMED BY:

HYDROTEST INSPECTION PERFORMED BY:

NAME:

ROY ZUKIWSKY

NAME:

DOUG LANGKOW

SIGNATURE:

Roy Zukowsky

SIGNATURE:

Doug Langkow

DATE:

OCT 28/11

DATE:

OCT 28/11