

Storage Tank Internal Visual Inspection Report



Organization: Husky

Inspection Date: 18/05/2010 12:00:00AM

Plant: East Central

Equipment ID: 66096450

Asset No: 66096450

System: 00001 Sylvan Lake Gas Plant 01-21-038-

Operating Unit: EC-SO-015 Sylvan Lake

UNIVERSAL SN 05-04-06-13848

Background

Description:	Tank, Lean Oil, 750 Bbl, S/W, N/C
--------------	-----------------------------------

Inspection

Inspector:	Chris Randt	Company:	Husky Energy	Internal Lining/Coating:	N
------------	-------------	----------	--------------	--------------------------	---

Inspection Comments

ID	Description	Condition	Location	NCR	Comments
V1	General (Other)	Good			

Inspection Summary

An internal visual inspection with UT thickness measurements was performed on the tank to determine its integrity. Tank was returned to service.

- Internal coating had no visible breaches.
- Floor measurements indicated no soil-side corrosion. This was only a spotcheck as Ops did not opt for a floorscan.
- Shell and roof UT indicate full thickness present.
- The internal piping and mechanisms were free from corrosion and appeared to be operable. No loose bolting or evidence of leaks present.

Lean Oil Tank- A# NA, Eq. ID 66096450
Sylvan Lake GP (01-21-038-02W5)
May 18, 2010
Attachment 1-1



