



# FIREBOX FLAME ARRESTOR SAFETY CERTIFICATE

CUSTOMER: Husky Energy DATE: Sept 4/13

LOCATION: Sylvan Lake TECHNICIAN: Stan Neu

## Firebox Identification

Manufacturer: Wenco Serial Number: 0704-262

Model Number: FAH34/18-20A

Max BTU Reading: 2.9mm btu/h Heat Rating KW: \_\_\_\_\_

The Pronghorn Technician mentioned above, under the work order listed below has purge tested the Firebox Flame arrestor described on this Certificate to the API 12N code of standards though the conduct of no less than 10 flash back tests, and is acceptable on this:

4 day of, September, 2013  
month year

Understanding that the condition of the unit is acceptable on the day of testing, it is the responsibility of the owner to ensure that it is kept in the current or better condition to maintain the safety certification. Please refer to the OH&S standards, "Safe Operation of Fired Equipment In Hazardous Location", for maintenance requirements.

Work Order Number: \_\_\_\_\_

Flame Arrestor Hole Size: .063"

Legal Survey Description: 1-21-38-2w5

Vessel S/N (Identifiers): TEG Heater

*stan Neu*

Technician Signature

Owner/Owner Representative Signature

Pronghorn Controls

Head Office: #101-4919-72 Ave. Calgary, AB, T2C 3H3

Tel 1 (403) 720-2526 Fax 1 (403) 720-6815 Toll Free 1-866-885-2526

Email: calgary@pronghorn.ca Website: www.pronghorn.ca

Version 2.1