



EQUIPMENT VISUAL EXTERNAL PERIODIC INSPECTION REPORT

EQUIPMENT # 66146013 REPORT # 20170322GGB UNIT W5-01 ANSEL;
DATE March 22, 2017 EQUIPMENT DESCRIPTION Single Well 3 Phase Inlet Separator

	Not Applicable	Action Required		Conditions Noted
<u>SHELL & HEADS</u>				
-LEAKAGE	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-PITTING & CORROSION	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-DISTORTION/BULGING/BLISTERING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-BOLTING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
<u>NOZZLES</u>				
-LEAKAGE	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-PITTING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-DISTORTION/BULGING/CRACKING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-BOLTING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-GASKETS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
<u>NOZZLE REINFORCING PADS</u>				
-LEAKAGE	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
-WEEPHOLE OPEN AND UNPLUGGED	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	None Noted
<u>LADDERS/WALKWAYS/PLATFORMS/STAIRWAYS</u>				
-CORRODED, BENT, BROKEN OR MISSING STRUCTURAL PARTS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
-LOOSE OR MISSING BOLTING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
-WORN STAIR TREADS & LADDER RUNGS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
<u>FOUNDATION AND SUPPORTS</u>				
-SPALLING, CRACKING OR SETTLING OF CONCRETE OR STEEL REINFORCED FOUNDATIONS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	
-EVIDENCE OF ANCHOR BOLT CORROSION OR DISTORTION	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
-EVIDENCE OF LOOSE ANCHOR BOLT NUTS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
-CORROSION, DISTORTION AND CRACKING OF STEEL SUPPORTS	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure in intact
-CONDITION OF FIREPROOFING	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
-ALLOWANCE FOR EXCHANGER EXPANSION	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
<u>PROTECTIVE COATING AND INSULATION</u>				
-EVIDENCE OF CUI (< 350° OR INTERMITTENT	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
-LOOSE OR DETERIORATED INSULATION OR ALUMINUM SHEATHING	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
-BREACH OF WEATHER PROOFING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Paint is in ok condition
-PAINT	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Paint is in ok condition



Form: QR-19.7g
Rev: 0, Date: Jan 29th, 2016

EQUIPMENT VISUAL EXTERNAL PERIODIC INSPECTION REPORT

	Not Applicable	Action Required		COMMENTS
<u>VESSEL TRIM</u>				
-LEAKAGE OR CORROSION	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	No sign
-INSULATION	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
-PAINT	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Paint is in ok condition
-RAT TAIL (< 350°)	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
-EVIDENCE OF CUI (< 350° OR INTERMITTENT	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
<u>MISCELLANEOUS</u>				
-NAMEPLATE PRESENT AND LEGIBLE	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Secure and legible
-PROV. REG. NUMBER ON VESSEL	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	
-HMIS SIGN PRESENT	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	
-VESSEL GROUNDING	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Though skid to piles
-DAVITS & LIFTING LUGS	<input checked="" type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	

OTHER

PRD was serviced last 2013

NEXT EXTERNAL INSPECTION DATE 2022

	YES	NO
COMPLETE IN SERVICE ENDORSEMENT REQUIRED PER THIS EXTERNAL INSPECTION	<input type="checkbox"/>	<input checked="" type="checkbox"/>

COMMENTS _____

AREAS OF CONCERN ARE NOTED ON THE EXTERNAL VISUAL DRAWING(S).

Inspector (PRINT NAME)

Inspector (SIGNATURE)

API #