

Tank Inspection Report

Approver: Ken Pope
Requisitioned By: Derek Hoskins
Manufacturer: GLM
Capacity: 1000 bbl

Approver #: 22-0713560 WO#: 4083037
Location: MAintenance Warehouse PO# 8400542169
Serial #: G99-242-57 Tank Type: HEAVY Oil Storage
Thickness: Floor 1/4 Shell Year Built: 1999

External Inspection

T61	Insulation	GOOD	FAIR	POOR
T64	Cladding	GOOD	FAIR	POOR
T32	Base / Landscaping	GOOD	FAIR	POOR
T14	Liner / Containment	GOOD	FAIR	POOR
T8	Ground Cable		YES	NO
T6	Ladder/ Stairway	GOOD	FAIR	POOR
T7	Platform	GOOD	FAIR	POOR
T41	Piping Alignment	GOOD	FAIR	POOR
T15	Shell	GOOD	FAIR	POOR
T44	Envirovault		YES	NO
T16	Roof	GOOD	FAIR	POOR
T11	Paint	GOOD	FAIR	POOR

N/A
N/A Disconnected (Maintenance Warehouse)
N/A
Removed From TASK
N/A Disconnected
Good
N/A

Internal Inspection


T11	Floor	GOOD	FAIR	POOR
V9	Shell	GOOD	FAIR	POOR
V10	Roof	GOOD	FAIR	POOR
V28	Firetube	GOOD	FAIR	POOR

Surface & Scale / Rust.

INTERNAL: GOOD BOWED OVALLED
FLANGE LEAKING: YES NO

V8	Nozzles	GOOD	FAIR	POOR
V7	Welds	GOOD	FAIR	POOR
V21	Anodes	GOOD	FAIR	POOR
V27	Coating	GOOD	FAIR	POOR

BACKWELDING REQ'D: YES NO
SCADA Nozzle
N/A
TYPE: N/A



Notes & Summary of Recommendations:

Backweir SCAA nozzle
Replace 2 Sting nozzles

Blace 4" Riser on VACUT
Replace Firetube.

FLOOR HAS MINOR UNDERSIDE CORROSION, SOME SURFACE SCALE RUST.

Tank Located At Husky Warehouse.

Inspection Interval: 5 yr

Entered in RBMI: ☐

Approvals
Inspector
Husky Inspector

Name Stephen BRYAN, IRIS NDT

Signature _____

Date Nov 27. 12
NOV 29 2012