

Equipment #: 66168164
Area: AS-Wildmere
Cost Centre:

Page 2 of 2



Tank Inspection Report

8460817115

Approver: Rick Fountain

Approver #: 22-0290577

WO#: 25640

Requisitioned By: Craig Rennie

Location: 13-19-48-4W4

PO# 8400802152

Manufacturer: Universal

Serial #: 021080-4

Tank Type: Heavy Oil Storage

Capacity: 1000 bbl

Thickness: Floor 1/4" Shell 1/4" 1/16"

Year Built: 2010

External Inspection

T61	Insulation	GOOD	FAIR	POOR
T64	Cladding	GOOD	FAIR	POOR
T32	Base / Landscaping	GOOD	FAIR	POOR
T14	Liner / Containment	GOOD	FAIR	POOR
T8	Ground Cable	YES	NO	
T6	Ladder / Stairway	GOOD	FAIR	POOR
T7	Platform	GOOD	FAIR	POOR
T41	Piping Alignment	GOOD	FAIR	POOR
T15	Shell	GOOD	FAIR	POOR
T44	Envirovault	YES	NO	
T16	Roof	GOOD	FAIR	POOR
T11	Paint	GOOD	FAIR	POOR

N/A

ON PLANKS

in Containment

ENTERED
JUNE 27/14

Internal Inspection

T11	Floor	GOOD	FAIR	POOR
V9	Shell	GOOD	FAIR	POOR
V10	Roof	GOOD	FAIR	POOR
V28	Firetube	GOOD	FAIR	POOR

Light Scale / Rusty

Light Scale / Rusty


INTERNAL GOOD BOWED OVALLED
FLANGE LEAKING: YES NO

V8	Nozzles	GOOD	FAIR	POOR
V7	Welds	GOOD	FAIR	POOR

BACKWELDING REQ'D: YES NO

V21	Anodes	GOOD	FAIR	POOR
V27	Coating	GOOD	FAIR	POOR

N/A
TYPE: N/A



Notes & Summary of Recommendations:

Downhole Location (00/14-19-48-4W4)

Tank in Good overall Condition.
Light Scale and Rust on Floor and
Shell Surface.

UT Readings Good 5 YR Turnaround
AS Per Husky UT Requirements.

Inspection
Interval: 5 yr

Entered in RBMI: ☒

Approvals
Inspector
Husky Inspector

Name
Stephen Bryan IRIS NDT

Signature
Stephen Bryan

Date
June 23/2014
JUN 27 2014

Type of Inspection: UT/VT
Test Technique: UT THICKNESS
Equipment: DMS2/ GRINDER/ SPOTLIGHT
Code: CLIENT SPECS/ CLIENT INFO

Client: HUSKY OPERATIONS
IRISNDT #: 176288
Location: 100/ 14-19-48-4 W4M,AB
Item Inspected: 1000 BBL TANK S/N# 021080-4



Date: 23-Jun-14
WO #: 25640
PO #: 8400002152
8400317115

Inspection Results: a ut and visual inspection was carried out as requested on 1000bbl tank , refer to page 2 for results.

REQ: CRAIG RENNIE

APP: RICK FOUNTAINE 2Z-0290577

AFE# 6050009

Unit#: 601 In: 1300 Out: 1400 Hrs: 1.0 In: _____ Out: _____ Hrs: _____ Personnel: STEPHEN BRYAN / LOGAN SKINNER	Kilometers: 25 Consumables: MIN	Interpretation by: STEPHEN BRYAN (Print)  (Signature) Client Representative (Print) I am in full agreement with report contents (Sign) 	SNT-TC-1A: 2 C.G.S.B.: 2 (Level) C.G.S.B. #: 12459
---	---------------------------------------	--	---

5311 - 88 Street, Edmonton, Alberta T6E 5T8 Phone: (780) 437-2022 fax (780) 436-4873
Calgary (403) 279-6121
Lloydminster (780) 675-6455
Barrhead (780) 674-3018
Nisku (780) 955-7616

Cold Lake (780) 626-6105
Fort McMurray (780) 743-1536
Red Deer (403) 347-1742

www.irisndt.com

Engineering, Calgary (403) 217-9684
Engineering, Edmonton (780) 437-2022
Rope Access Services (780) 437-2022
Offices also located in USA and UK

IRISNDT-E-2015E