

Equipment #:

Area:

Cost Centre:

66155561
AS-Edgerton
/Dina

Page 2 of 2



Tank Inspection Report

Approver:

Dee Nelson

Approver #:

22-2000425

WO#:

4094156

Requisitioned By:

Roger Skarood

Location:

100/16-1-45-1 W4

PO#

8400800876

Manufacturer:

Wilco Industries

Serial #:

016349-13

Tank Type:

Heavy Oil Storage

Capacity:

1000661

Thickness:

Floor 1/4" Shell 1/4" 3/16"

Year Built:

2008

External Inspection

T61	Insulation	<u>GOOD</u>	FAIR	POOR
T64	Cladding	<u>GOOD</u>	FAIR	POOR
T32	Base / Landscaping	<u>GOOD</u>	FAIR	POOR
T14	Liner / Containment	<u>GOOD</u>	FAIR	POOR
T8	Ground Cable	<u>YES</u>	NO	
T6	Ladder/ Stairway	<u>GOOD</u>	FAIR	POOR
T7	Platform	<u>GOOD</u>	FAIR	POOR
T41	Piping Alignment	<u>GOOD</u>	FAIR	POOR
T15	Shell	<u>GOOD</u>	FAIR	POOR
T44	Envirovault	<u>YES</u>	NO	
T16	Roof	<u>GOOD</u>	FAIR	POOR
T11	Paint	<u>GOOD</u>	FAIR	POOR

N/A

on PLANKS

In Containment

ENTERED
June 25/14

N/A To be Disconnected And Relocated.

GOOD

N/A

Internal Inspection

T11	Floor	<u>GOOD</u>	FAIR	POOR
V9	Shell	<u>GOOD</u>	FAIR	POOR
V10	Roof	<u>GOOD</u>	FAIR	POOR
V28	Firetube	<u>GOOD</u>	FAIR	POOR

Light Scale / Rusty

Light Scale / Rusty.

INTERNAL GOOD BOWED OVALLED
FLANGE LEAKING: YES NO

V8 Nozzles

GOOD FAIR POOR

V7 Welds

GOOD FAIR POORBACKWELDING REQ'D: YES NO

V21 Anodes


GOOD FAIR POOR

V27 Coating

GOOD FAIR POOR

N/A

TYPE: N/A



Notes & Summary of Recommendations:

Surface Scale on Floor AND
Shell, UT Readings Suggest
Floor AND TANK IN GOOD
CONDITION FOR 5YR Turnaround.

TANK IN GOOD Overall Condition.

Surplus Tank To be Relocated.

Inspection
Interval:

5 yr

Entered in RBMI ☒

Signature

Date

Approvals

Inspector

Husky Inspector

Stephen Bryan

IRIS NDT

May 28/2014
JUN 20 2014