

Equipment #: 6601555601  
Area: AS - main right  
Cost Centre: 25558

Page 2 of 2



### Tank Inspection Report

Approver: LARRY Kingswood Approver #: 22-0495036 WO#: 25013517  
Requisitioned By: RAY TRACHUK Location: 100/16-1-45-1W4 PO#: 8400530258  
Manufacturer: WILCO Serial #: 016349-13 Tank Type: HEAVY OIL Storage  
Capacity: 1000 bbl Thickness: Floor 1/4 Shell 1/4 3/16 Year Built: 2008

#### External Inspection

T61	Insulation	<u>GOOD</u>	FAIR	POOR
T64	Cladding	<u>GOOD</u>	FAIR	POOR
T32	Base / Landscaping	<u>GOOD</u>	FAIR	POOR
T14	Liner / Containment	<u>GOOD</u>	FAIR	POOR
T8	Ground Cable	<u>YES</u>	<u>NO</u>	
T6	Ladder/ Stairway	<u>GOOD</u>	FAIR	POOR
T7	Platform	<u>GOOD</u>	FAIR	POOR
T41	Piping Alignment	<u>GOOD</u>	FAIR	POOR
T15	Shell	<u>GOOD</u>	FAIR	POOR
T44	Envirovault	<u>YES</u>	<u>NO</u>	
T16	Roof	<u>GOOD</u>	FAIR	POOR
T11	Paint	<u>GOOD</u>	FAIR	POOR

N/A

ON PLANKS

In Containment

Good

N/A

#### Internal Inspection

T11	Floor	<u>GOOD</u>	FAIR	POOR
V9	Shell	<u>GOOD</u>	FAIR	POOR
V10	Roof	<u>GOOD</u>	FAIR	POOR
V28	Firetube	<u>GOOD</u>	FAIR	<u>POOR</u>


INTERNAL: GOOD BOWED OVALLED  
FLANGE LEAKING: YES NO

V8	Nozzles	<u>GOOD</u>	FAIR	POOR
V7	Welds	<u>GOOD</u>	FAIR	POOR
V21	Anodes	<u>GOOD</u>	FAIR	POOR
V27	Coating	<u>GOOD</u>	FAIR	POOR

BACKWELDING REQ'D: YES NO

N/A

TYPE: N/A



#### Notes & Summary of Recommendations:

De Former Busted

Replace Firetube  
UPGRADE Sch 40 String  
Nozzle

5 YRS with upgrades.

Inspection  
Interval: 5 yr

Entered in RBMI: ☐

Approvals  
Inspector  
Husky Inspector

Name  
Stephen BRYAN IRIS NDT

Signature  
Ray Trachuk

Date  
Nov 2, 12  
NOV 05 2012

Type of Inspection: VT /UT	Job/P.O.#: SEE BELOW	IRISNDT #: 165297	Date: 02-Nov-12
Test Technique: UT THICKNESS	Client: HUSKY OPERATIONS		
Equipment: DMS2/ FLASHLIGHT/ GRINDER	Location: 16-1-45-1 W4M AB		
	Item Inspected: 1000 BBL TANK S/N#		
	Code: CLIENT INFO		

A UT and visual inspection was carried out as requested on a 1000 BBL tank, see page 2 for inspection results.

REQ: RAY TRACHUK  
APP: LARRY KINGSWOOD 2Z-0495036  
W.O# 25013517  
P.O# 8400530258

Unit#: 601	Kilometers: 90
In: 1100	Out: 1530 Hrs: 4.5
In: _____	Out: _____ Hrs: _____

Personnel:  
STEPHEN BRYAN / DANIEL LERICHE

Consumables:  
2 GAS MONITORS

time charged includes stanby time

Interpretation by:  
STEPHEN BRYAN

(Print)

Signature

Client Representative:

I am in full  
agreement with  
report contents

(Sign)

SNT-TC-1A

C.G.S.B.

C.G.S.B. #

(Level)  
12459