




Without MFE		
.170 - up	5 yr	
.160 - .169	4 yr	
.150 - .159	3 yr	
.140 - .149	2 yr	
.130 - .139	1 yr	
under .130	Patch	
	Replace	
	Floor	
	Shell	

S/N: 29085-10 (Tank 1)

Location: 103/9-11-47-5W4

With MFE		
.140 - .150	5 yr	
.130 - .139	4 yr	
.120 - .129	3 yr	
.110 - .119	2 yr	
.100 - .109	1 yr	
under .100	Patch	
	Replace	
	Floor	
	Shell	



Comments:

Tank In Good Overall Condition For A 5YR Turnaround. NO Additional Repairs Required.

Inspected by: Stephen Bryan

Date: May 28, 2019

Husky Inspector: [Signature]


Date: July 30, 2019

Terry Neufeld

Type of Inspection: VT **Rev:** 3.0**Client:** HUSKY OIL OPERATIONS**Date:** 2019-May-28**Test Technique:** UT thickness(4.2)**IRISNDT #:** LYN1900860**WO #:** 81391483**Equipment:** DMS2 / flashlight / grinder**Location:** 103/ 9-11-47-5 W4M**PO #:** 8401358779**Code/Standard:** client information**Item Inspected:** 1000 bbl tank 1 S/N# 29085-10

a UT and visual inspection was carried out as requested on 1000bbl tank, refer to attached pages for additional information.

1000bbl tank 1 S/N# 29085-10: The tank is in good overall condition for a 5yr turnaround. no additional repairs/ upgrades required.

**DMS 2 S/N# 31074 CAL DATE : JAN9 2019.****F2HE PROBE S/N# SCA2097****APPROVER:** Jay Sinclair ZZ-8000441**Requested by** Randy Chiuurka**Inspection Limitation(s):** oil /shale deposits on the shell and piping.

Unit#: 767 Kilometers: 0
In: _____ Out: _____ Hrs: _____
In: _____ Out: _____ Hrs: _____

Personnel:
STEPHEN BRYAN / NIGEL GEARIN

Consumables:
MIN

Interpretation by:**Stephen Bryan**

SNT-TC-1A: _____

(Print)

C.G.S.B.: _____
(Level)

(Sign)

C.G.S.B #: 12459

Client Representative:**Terry Neufeld**

(Print)

I am in full
agreement with
report contents

(Sign)

5311 - 86 Street NW, Edmonton, Alberta T6E 5T8 Phone (780) 437-4747 Fax (780) 436-4873
Calgary (403) 279-6121 Cold Lake (780) 826-6105
Lloydminster (780) 875-6455 Fort McMurray (780) 743-1536
Barrhead (780) 674-3018 Red Deer (403) 347-1742
Nisku (780) 955-7616 www.irisndt.com

Engineering, Calgary (403) 217-9684
Engineering, Edmonton (780) 437-2022
Rope Access Services (780) 437-2022
Offices also located in USA and UK