

Certificate of Inspection Permit

HUSKY OIL OPERATIONS LTD
BOX 6525 STN D
CALGARY/WESTERN CDA UPSTREAM
ATTN: RON CHAPMAN
CALGARY, AB
T2P 3G7

PREFERRED RE-INSP. INTERVAL: 1.00 Yr.

YEAR BUILT: 2007

CRN: U0192.2

SERIAL #: 12306200

VOLUME: 6.456 M3

HEATING SURFACE:

SURFACE AREA:

COMPANY CODE: V101

DESCRIPTION: INLET SEPARATOR

LOCATION: ANSELL GAS PLANT

MANUFACTURER: TOROMONT PROCESS SYSTEMS

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	Safety Valves	
						CAPACITY	LOCATION
VESSEL	2689 KPA	66 C	-29 C	SV1			TO BE INSTALLED

OWNER INSTRUCTIONS/REMARKS:

Contact the ABSA Safety Codes Officer before placing the vessel/boiler in service.

Vessel/Boiler to be installed in accordance with the Safety Codes Act and Regulations.

Verify that vessel/boiler is protected by an acceptable ASME Code pressure relief device, of adequate capacity, set at no more than maximum pressure authorized and installed in accordance with the Safety Codes Act & Regulations.

Safety Codes Officer: SIMPSON, NORMIN

Signature: 

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.