

EQ# 66068048

Certificate of Inspection

HUSKY ENERGY INC
BOX 6525 STATION D
707-8 AVENUE SW, SUITE 1443 NWCP
ATTN: MARGARET NEWSOME
CALGARY, AB
T2P 3G7

PREFERRED RE-INSP. INTERVAL: 3.00 Yr.

YEAR BUILT: 2001
CRN: P7239.2
SERIAL #: 38047A

LOCATION: LSD 12-5-54-20 W5M (GALLOWAY GAS PLT)
DESCRIPTION: INLET SEPARATOR/SLUG CATCHER
COMPANY CODE: V-200
MANUFACTURER: RNG PRO-TECH INC.

VOLUME: 54.17 M3
HEATING SURFACE:
SURFACE AREA:
Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	3447 KPA	38 C	-46 C	SV1			TO BE INSTALLED

OWNER INSTRUCTIONS/REMARKS:

CONTACT THE ABSA SAFETY CODES OFFICER BEFORE PLACING THE VESSEL/BOILER IN SERVICE.

VESSEL/BOILER TO BE INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT AND REGULATIONS.

VERIFY THAT VESSEL/BOILER IS PROTECTED BY AN ACCEPTABLE ASME CODE PRESSURE RELIEF VALVE, OF ADEQUATE CAPACITY, SET AT NO MORE THAN MAXIMUM PRESSURE AUTHORIZED AND INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT & REGULATIONS.

Safety Codes Officer: IONEL, BLAIR

Signature: 

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.