

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS (2019)
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

626024

1. Manufactured and certified by **CALHEX INDUSTRIES LTD. 9515 48TH STREET S.E., CALGARY, ALBERTA, CANADA T2C 2R1**
(Name and address of Manufacturer)

2. Manufactured for **Husky Oil Operations Ltd. 707 - 8th Avenue S.W. Calgary, AB T2P 1H5**
(Name and address of Purchaser)

3. Location of installation **Husky Oil Ansell Gas Plant Edson, AB LSD# - 07-27-051-19-W5M**
(Name and address)

4. Type **Horizontal** **Heat Exchanger** **12-0779**
(Horizontal, vertical, or sphere) (Tank, separator, jkt. vessel, heat exch., etc.) (Manufacturer's serial number)

V9688.21 **12-0779-S Rev. 0 & T Rev. 0** **2012**
(CRN) (Drawing No.) (National Board Number.) (Year Built)

5. ASME Code, Section VIII, Div. 1 **2010 & 2011** **2714**
(Edition and Addenda (date)) (Code Case Number) (Special Service per UG-120(d))

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multi-chamber vessels.

6. Shell (a) Number of course(s): **2** (b) Overall length (ft & in.): **47' - 8.750"**

Course(s)			Material		Thickness		Long. Joint (Cat.A)			Circum. Joint (Cat. A,B, & C)			Heat Treatment	
No.	Diameter, in.	Length (ft & in.)	Spec./Grade or Type		Nom.	Corr.	Type	Full,Spot,None	Eff.	Type	Full,Spot,None	Eff.	Temp.	Time
1	23"	39' - 8.750"	SA333-6		0.500"	0.0625"	S	None	0.85	7/1	Spot *	0.70	-	-
1	23"	8' - 0"	SA333-6		0.500"	0.0625"	S	None	0.85	7/1	Spot *	0.70	-	-

7. Heads: (a) (b)
(Material spec. number, grade or type) (H.T. - time & temp.) (Material spec. number, grade or type) (H.T. - time & temp.)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full,Spot,None	Eff.
(a)														
(b)														

If removable, bolts used (describe other fastening)

(Material spec. number, grade, size, number)

8. Type of jacket Jacket closure (Describe as ogee and weld, bar, etc.)
If bar, give dimensions If bolted, describe or sketch.

9. MAWP **400** **15** psi at max. temp. **183** **163** °F Min. design metal temp. **-49** °F at **400** psi.
(Internal) (External) (Internal) (External)

10. Impact test **No. exempt per UCS-66(a)(c)(d)(g), Fig. UCS-66 Note (c) & UCS-67(a)2.** at test temperature of **-** °F.
(Indicate yes or no and the component(s) impact tested)

11. Hydro., pneu., or comb. test pressure **520 psi** Proof test **-**

Items 12 and 13 to be completed for tube sections.

12. Tubesheet: **SA516-70N** **23"** **1.5625"** **0.125"** **Welded**
(Stationary (material spec. no.)) (Diameter, (subject to press.)) (Nominal thickness) (Corr. Allow.) (Attachment (welded or bolted))

SA179 ** **0.750"** **16 BWG** **440** **Straight**
(Material spec. no., grade or type) (O.D.) (Nominal thickness) (Number) (Type (straight or U))

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell: (a) No. of course(s): **2** (b) Overall length (ft & in.): **2' - 10"**

Course(s)			Material		Thickness		Long. Joint (Cat.A)			Circum. Joint (Cat. A,B, & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type		Nom.	Corr.	Type	Full,Spot,None	Eff.	Type	Full,Spot,None	Eff.	Temp.	Time
2	23"	1' - 5"	SA333-6		0.500"	0.0625"	S	None	1.0	1/7	Spot *	0.70	-	-

15. Heads: (a) **SA350-LF2 CL.1** (b) **SA350-LF2 CL.1**
(Material spec. number, grade or type) (H.T. - Time & Temp.) (Material spec. number, grade or type) (H.T. - Time & Temp.)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full,Spot,None	Eff.
(a)	End	2.75"	0.0625"						36"					
(b)	End	2.75"	0.0625"						36"					

If removable, bolts used (describe other fastening)

(24) 1.50" x 9.250" Lg. SA193-B7 UNC Studs / (48) 1.50" SA194-2H UNC Nuts

(Material spec. number, grade, size, number)

16. MAWP 400 15 psi at max. temp. 158 158 °F Min. design metal temp. -49 °F at 400 Psi
(Internal) (External) (Internal) (External)

17. Impact test No, exempt UCS-66(a)(c)(d)(g), Fig. UCS-66 Note (c) & UCS-67(a)2. at test temperature of - °F.
(Indicate yes or no and the component(s) impact tested)

18. Hydro, pneu., or comb. test press. 520 psi Proof test -

19. Nozzles, inspection, and safety valve openings:

[illegible]

22. Remarks: (2) 24" 300 CL RFWN Channel Flanges - SA350-LF2 CL.1

SAFETY VALVES:	P.S.V. on piping per UG-125 (g) to be installed by owner.	CUBIC CAPACITY:	123.04 cu. ft.
SURFACE AREA:	4146.9 sq. ft.		
SERVICE:	Inlet Gas Heat Exchanger	* RT2 – Spot per UW-11(a)5(b). ** Tube Length – 48' – 0" Lg.	
ITEM #:	E-102B	Constructed to Drawing # 12-0779–S Rev. 1 & T Rev. 0.	

U Certificate of Authorization Number.	<u>33238</u>	Expires	<u>April 22</u>	, 20	<u>14</u>
Date	<u>DEC 14 2012</u>	Name	<u>Calhex Industries Ltd.</u>	Signed	<u></u>
		(Manufacturer)			(Representative)

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of **ALBERTA** and employed by **ABSA** of **CALGARY, AB, CANADA** have inspected the pressure vessel described in this Manufacturer's Data Report on _____, 20_____, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date DEC 14 2012 Signed  (Authorized Inspector) Commissions NB14678 AB428
(National Board (incl. endorsements), State, Province, and number)

U Certificate of Authorization Number _____ Expires _____, 20____

Date _____ Name _____ Signed _____

(Assembler) (Representative)

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board (incl. endorsements), State, Province and number.)

