


Location Name:	ANSELL GAS PLANT	LSD:	07-27-051-19W5
A#:	A0157978	Equipment/Tag No.	T-101
Equipment Description:	STABILIZER TOWER	Serial Number:	1704.201
		CRN: (or other ID#)	F2109.2
MAWP:	485 PSI	Design Temp:	354°F
Shell Material:	SA 516 70	Head Material:	SA 516 70
Shell Thickness:	0.625"	Head Thickness:	0.543"
Corrosion Allowance:	3.2MM	Date Built:	1984
Size:	INS	Manufacturer:	N/L

Notes: CML 30 EROSION NOTED. NO ACCESS TO CML LOCATIONS ABOVE BOTTOM PLATFORM (00,05,10)







Ultrasonic Corrosion Survey

Survey Name: Husky Energy

Date: Jul 11, 2014

Inspector: C. Graham

LSD: 07-27-051-19W5 Area: Ansell Location: Gas Plant
A #: A0157978 Tag Number: T-101 Vessel Name: Stabilizer Tower
CRN: F2109.2 Year Built: 1984 Serial Number: 1704.201
Vessel CA: 3.2 mm Manufacturer:
Shell MAWP: 485psi MAWTF: 354°F Tube MAWP: MAWTF:

TML Description	Baseline	Material:	SA-516-70
00 Head	2014	T Min	Corr. Rate
Shape: Ellipsoidal	Min	Flag	CA
OD:	Avg	Nominal	
Spec: ASME VIII Div.1	Comments: No Access		Remaining Life:
			Retirement Date:

TML Description	Baseline	Material:	SA-516-70
05 Shell	2014	T Min	Corr. Rate
Shape: Cylindrical	Min	Flag	CA
OD:	Avg	Nominal	
Spec: ASME VIII Div.1	Comments: No Access		Remaining Life:
			Retirement Date:

TML Description	Baseline	Material:	SA-516-70
10 Shell	2014	T Min	Corr. Rate
Shape: Cylindrical	Min	Flag	CA
OD:	Avg	Nominal	
Spec: ASME VIII Div.1	Comments: No Access		Remaining Life:
			Retirement Date:

TML Description	Baseline	Material:	SA-516-70
15 Shell	2014	T Min	Corr. Rate
Shape: Cylindrical	Min	Flag	CA
OD:	Avg	Nominal	
Spec: ASME VIII Div.1	Comments:		Remaining Life:
			Retirement Date:



Ultrasonic Corrosion Survey

Survey Name: Husky Energy

Date: Jul 11, 2014

Inspector: C. Graham

LSD: 07-27-051-19W5 **Area:** Ansell **Location:** Gas Plant
A #: A0157978 **Tag Number:** T-101 **Vessel Name:** Stabilizer Tower
CRN: F2109.2 **Year Built:** 1984 **Serial Number:** 1704.201
Vessel CA: 3.2 mm **Manufacturer:**
Shell MAWP: 485psi **MAWTF:** 354°F **Tube MAWP:** **MAWTF:**

TML Description		Baseline				Material: SA-516-70
20 Shell		2014	Flag	CA	Nominal	T Min Corr. Rate
Shape: Cylindrical	Min	16.480	12.675	3.200	15.875	
OD:	Avg	16.740				Remaining Life:
Spec: ASME VIII Div.1	Comments:					Retirement Date:

TML Description		Baseline				Material: SA-516-70
25 Head		2014	Flag	CA	Nominal	T Min Corr. Rate
Shape: Ellipsoidal	Min	15.320	10.592	3.200	13.792	
OD:	Avg	15.930				Remaining Life:
Spec: ASME VIII Div.1	Comments:					Retirement Date:

TML Description		Baseline				Material: A-234-WPB
30 Nozzle		2014	Flag	CA	Nominal	T Min Corr. Rate
Shape: 90° Elbow	Min	7.520	7.623	1.089	8.712	2.540 1.537
OD: 2.375"	Avg	7.770			Assumed	Remaining Life: 127.53 Years
Spec: ASME VIII Div.1	Comments: Erosion Noted					Retirement Date: 1/19/2142

TML Description		Baseline				Material: A-234-WPB
35 Nozzle		2014	Flag	CA	Nominal	T Min Corr. Rate
Shape: 90° Elbow	Min	18.800	15.958	2.280	18.237	
OD: 6.625"	Avg	19.180			Assumed	Remaining Life:
Spec: ASME VIII Div.1	Comments:					Retirement Date:



Ultrasonic Corrosion Survey

Survey Name: Husky Energy

Date: Jul 11, 2014

Inspector: C. Graham

LSD: 07-27-051-19W5	Area: Ansell	Location: Gas Plant
A #: A0157978	Tag Number: T-101	Vessel Name: Stabilizer Tower
CRN: F2109.2	Year Built: 1984	Serial Number: 1704.201
	Vessel CA: 3.2 mm	Manufacturer:
	Shell MAWP: 485psi	Tube MAWP: MAWTF:
	MAWTF: 354°F	

TML Description	Baseline	Material: A-234-WPB
40 Nozzle	2014	
Shape: 360° Circ	Min 15.060	Flag 13.335
OD: 3.5"	Avg 15.320	CA 1.905
Spec: ASME VIII Div.1	Comments:	Nominal 15.240
		T Min Assumed
		Corr. Rate
		Remaining Life:
		Retirement Date:

A157978

C-600

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

A157978

1. Manufactured and certified by Vada Ind. Steel-Flo Div. 100 Stockton Avenue Okotoks, Alberta
(Name and address of manufacturer)
2. Manufactured for Cord Project Ltd. 4th Floor 10201 Southport Rd. S.W. Calgary, Alta
(Name and address of purchaser)
3. Location of installation User-Western Decalta L.S.D. -10, -12, -19, -2, -W5M
(Name and address)
4. Type Vertical 1704-201 F-2109.2 SFV1704-201 Rev. 3 1984
(Mount or vert. type) (After serial No.) (CRN) (Drawing No.) (Mat'l. Bt. No.) (Year Built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1983
Year

- to Winter 1983
Addenda (Date)
6. Shell: SA 516-70 .625 .125" 2'6" 67' 10"
(Mat'l. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (overall) (ft. & in.))
7. Seams: DBL Butt Full 1.0 1125° 3/4 hr DBL Butt Full 7
(Long. Welded, Del. Sngl. Lap, Butt) (R.T. (Spot or Full)) (ET (in.)) (H.T. Temp. (F)) (Time (hr)) (Girth (Welded, Del. Sngl. Lap, Butt)) (R.T. (Spot or Full)) (No. of Courses)
8. Heads: (a) Mat'l. SA 516-70 (Spec. No., Grade) (b) Mat'l. SA 516-70 (Spec. No., Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Concave or Convex)
(a)	Top	.543	.125			2:1			30"	Concave
(b)	Bottom	.543	.125			2:1			30"	Concave

If removable, bolts used (describe other fastenings):

(Mat'l., Spec. No., G., Size, No.)

9. MAWP 486 psi at max. temp. 354 °F
Min. temp. (when less than -20°F) °F. Hydro., pneu., or comb. test pressure 729 psi.

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat'l.	Nom. Thk.	Reinforcement Mat'l.	How Attached	Location
See Remarks								

11. Support: Skirt Yes Lugs 2 Legs Other Attached Welded to Heads/Shell
(Yes or no) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: See attached U4 form for Item #10
(Name of part, item number, Mfg.'s name and identifying stamp)

Volume = 313.9 Ft³Cord Projects P.O. #CPL-177-2000-21T-101 Stabilizer Tower (Sour Service)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 18,780 expires Jan 86.
Date 11/28/84 Co. name Vada Ind. Steel-Flo Div. Signed [Signature] (Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Vada Ind. Steel-Flo Div. 100 Stockton Avenue Okotoks, Alta
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Alberta and employed by General Safety Services, Boilers Branch have inspected the component described in this Manufacturer's Data Report on Nov 28, 19 84, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
Date Nov 28, 84 Signed [Signature] Commissions [Signature] (Not a Board member) (Not a State, Prov. and No.)

A15 7978

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

A157978

1. Manufactured and certified by Vada Ind. Steel-Flo Div. 100 Stockton Avenue Okotoks, Alberta
(Name and address of manufacturer)

2. Manufactured for Cord Projects Ltd. 4th Floor, 10201 Southport Rd. S.W. Calgary, Alta
(Name and address of purchaser)

3. Location of installation User-Western Decalita L.S.D. -10,-12,-19,-2,-W5M
(Name and address)

4. Type Vertical 1704-201 F-2109.2 SFV 1704-201 Rev. 3 1984
(Horiz., vert., tank, etc.) (Fig's. serial No.) (CRN) (Tag) (Mfr's. Bd. No.) (Year built)

Data Report Item Number		Remarks						
Purpose	No.	Diam Size	Type	Material	Thk	Reinforce Material	How Att.	Location
Inlet/TE/TW/TI	7	2"	RFWN	SA 106-B	.343	Weld Metal	Welded	Shell
Reboiler Feed	1	4"	RFWN	SA 106-B	.531	Weld Metal	Welded	Shell
Vap. Return	1	6"	RFWN	SA 106-B	.718	Weld Metal	Welded	Shell
Bridle	2	3"	RFWN	SA 106-B	.437	Weld Metal	Welded	Shell
M-ways	2	20"	RFWN	SA 516-70	.625	SA 516-70	Welded	Shell
Vap. out/Liq/out	2	2"	RFWN	SA 106-B	.343	Weld Metal	Welded	Heads

Date 11/28/84 Co. name Vada Ind. Steel-Flo Div. Signed L. Davies
(Date) (Manufacturer) (Representative)

Date NOV 28, 84 Signed Schepers Commissions _____
(Date) (Authorized Inspector) (Name, Board (incl. endorsements), State, Prov., and No.)

(12/82)

This form (E00118) is available from the Order Dept., ASME, 345 E. 47 St., New York, N.Y. 10017