

VESSEL

299-01-00V-A2916624

new

VESSEL

HUS-7 PRESSURE VESSEL INSPECTION REPORT

Equipment Location: <u>Production Warehouse (Lloyd)</u>	Equip #: <u>A-2916624</u>	Report #: <u>PWH-94-372</u>
Registration #: <u>A-2916624</u>	CRN #: <u>K2422.23</u>	Serial #: <u>2532</u>
Equipment Description: <u>2 phase separator</u>	Service: <u>GAS</u>	
Date of Inspection: <u>06-16-94</u>	Next Inspect. Date: _____	
Inspected Under Code(s):	☐ B31.1 ☐ B31.3 ☐ Sec 1 ☐ Sec V ☐ Sec IX ☐ CSA B51 ☒ Sec VIII Div I ☒	
	☐ Z183 ☐ Z184 ☐ Eng. Specs. ☐ Other _____	
Type of Inspection:	☒ External ☐ Internal ☒ VT ☐ RT ☒ UT ☐ MT ☐ PT ☐	
	☐ LT ☐ HT ☐ Other (specify): _____	

1.0 GENERAL:	
MAWP: <u>120PSI</u> <u>4965 KPA</u>	at <u>100°F</u> <u>38°C</u>
Safety Valve: Yes: ☒ No: _____	Capacity: _____
Setting: kPa: <u>4964</u> psi: <u>720</u>	If yes, ID#: _____ Inlet Size: <u>1"</u>
Capacity: USGM: _____ SCFM: <u>3562</u>	Serial No: <u>94C0026</u> CRN: <u>060449.2</u>
Safety Valve Serviced: Yes: _____ No: ☒	PPHS: _____ Code: <u>UV</u>
Last Service Date: _____	New: <u>/</u> Date: <u>02/92</u>
Vessel Has Manway: Yes: _____ No: ☒	Inspection Port: ☒
Welders Qualified: Yes: _____ No: _____	Unknown: ☒
Names Of Welders: _____	
WPS#: _____	Registration #: _____

2.0 REMARKS:	<u>Built By: RTV, Yr. built: 03/94, Shell Mat'l: SA-516-70, THK: 15.87</u> <u>Head Mat'l: SA-516-70/THK. 15.87, CORR. ALL 3.17mm, M.O.M.T. -20°F / -29°C</u> <u>Size: 610X1525mm</u> <u>UT readings indicate no wall loss in the spots scanned.</u> <u>New Equipment was not in operations, at the time of Inspections</u> <u>Separator is externally coated, which may affect the UT Readings</u>
---------------------	---

Nonconformance Reports Issued: Yes: ☐ No: ☒	Reference #: _____
New Material Identified: Yes: ☒ No: ☐	N/A: ☐
Shell Condition: Good: ☒ Fair: ☐ Poor: ☐	Failure: ☐
Pressure Test: <u>NA</u> kPa on shell	
Hold Time Under Pressure: <u>NA</u> minutes	Pass: _____ Fail: _____

3.0 RECOMMENDATIONS:	<u>Local A.I. to be notified prior to equipment put</u> <u>into service, of the facilities it will be assigned.</u>
-----------------------------	--

4.0 STATUS	
Suitable for further service: Yes: ☒ No: ☐	
Repairs required: Yes: ☐ No: ☐ N/A: ☒	
Repairs completed: Yes: ☐ No: ☐ N/A: ☒	
Attached Reports: Yes: ☒ No: ☐ N/A: ☐	

Inspected by:

Distribution:

Reading File

Chief Inspector

A. Matteis
B. Simonov

Remarks (Continued)

2 phase separator
Reg.# A.2916624



