



Turn Over Package

For



Husky Energy		Non Pressure Storage		Husky Purchase Order No. _____	
Data Collected By: <u>CT</u>		Entry Date: _____			
Equipment Class	☐ Bin ☐ Gas Boot ☐ Silo ☒ Tank ☐ Sump	Parent Asset No.: _____			
Equipment Description: <u>400BBL, LINED, INSULATED</u>		Exist. Equip. ID: _____		Tag No.: _____	
Unit Yard	Acquis Value: \$ <u>37,165.74</u>	Acquis Date: _____			
Equipment Status:	☐ In-Service Fully Utilized ☐ In Service Under-utilized ☐ Idle ☐ Scrap				
Ownership Status:	☐ Leased ☐ Rented ☒ Owned				
Manufacturer:	<u>HIGHLAND PROJECTS</u>		Year Built:	<u>2013</u>	
Equipment Condition:	Model No.: _____		Serial No.:	<u>SEE ATTACHED</u>	
Construction:	☒ Skidded ☐ Packaged ☐ Housed ☐ Packaged Portable ☐ Packaged Stationary				
Skid Weight:	_____ Kg / Lbs	Skid Size:	W _____ x L _____ x H _____	m / ft	
Common Characteristics					
Fluid Description:	<u>WATER</u>	Service:	☒ Sweet ☐ Sour	Volume:	<u>64</u> m ³ / ft ³
MAWP:	<u>11602 x .04 VAC</u> kPag / psig	@ Max. Temp:	<u>30</u> °C / °F	MDMT:	_____ °C / °F
Diameter:	<u>144</u> mm (in)	Length/Height (S/S):	_____ m / ft	Depth:	_____ m / ft
Shell Mat'l:	<u>A36</u>	Shell Thickness:	<u>3/16"</u> mm (in)	Shell C.A.:	_____ mm / in
Floor Mat'l:	<u>A36</u>	Floor Thickness:	<u>1/4"</u> mm (in)	Floor C.A.:	_____ mm / in
Roof Mat'l:	<u>A36</u>	Roof Thickness:	<u>3/16"</u> mm (in)	Roof C.A.:	_____ mm / in
Nozzle Mat'l:	<u>A106</u>	Nozzle Thickness:	<u>.237</u> mm (in)	Nozzle Rating:	<u>150</u> Ansi
Insulated:	☒ Yes ☐ No	Insulation Type	<u>Urethane</u>	Insulation Thick.:	_____ mm / in
# Manways:	<u>1</u>	# of Inspection Ports:	<u>1</u>	Painted / Primed:	☐ Yes ☒ No
Secondary Containment Type:	<u>N/A</u>	☐ Earthen Clay ☐ Imperious Synthetic Material ☐ Double Wall ☐ Other _____			
Internals:					
Component Types:	<u>5'x5' VAULT</u>	Component Man.	<u>A36</u>	Component Model:	_____
Component Removable:	☐ Yes ☐ No	Component C.A.:	_____ mm / in		
Internal Coating:	☒ Yes ☐ No	Int. Coating / Cladding Type:	<u>DEVCO 253, ELASTOMERIC SEALER</u>		
Additional Characteristics for Tank					
Tank Type:	☐ Underground ☒ Surface	# of Walls:	☐ single ☐ Double		
Design Standard:	☐ API 650 ☐ API 620 ☒ API 12F ☐ Other				
Fabrication Type:	☒ Shop ☐ Field				
Pressure Protection:	☐ Vent ☐ Thief Hatch Vacuum Breaker Manufacturer: _____ ☐ Vacuum Breaker Vacuum Breaker Model: _____				
Fire Tubes:	☐ Yes ☐ No Vacuum Breaker Service Date: _____				
# of Firetube:	_____	Firetube S/N:	_____	Firetube Rating:	_____ Btu/hr
Desand Type:	_____	Desand Connection:	_____ mm / in	Truck Connection:	<u>3</u> mm (in)
Additional Characteristics for Gas Boot					
Prov.Reg. No. (A#)	_____	CRN#	_____		
Head Mat'l:	_____	Head Thickness:	_____ mm / in	Head C.A.:	_____ mm / in
Comments					
Material Transfer Information					
Transfer Recorded by: _____		Date: _____			
From	LSD _____	Sec _____	Twp _____	Rge _____	W/ _____
Transfer Yard _____					
To	LSD _____	Sec _____	Twp _____	Rge _____	W/ _____
Facility _____					
Receiving AFE: _____					

	SERIAL NUMBER LIST	Effective Date	Procedure ID	
		April 2012		
	400BBL Tanks	Page 1 of 1	Revision	
			0	

Job #		Customer
WO-820		Husky

HUSKY PO#	TANK SERIAL NUMBER
8400724430	4982, 4983, 4984, 41-6164, 41-6165, 4991
8400724426	4985, 4986, 4990, 4992, 4994, 4996
8400724423	41-6172, 41-6173, 41-6174, 41-6175, 41-6176, 41-6177
8400724420	41-6171, 41-6166, 41-6167, 41-6168, 41-6169, 41-6170
8400724416	41-6179, 41-6180, 41-6181, 41-6182, 41-6184, 41-6185
8400724414	41-6178, 41-6183, 41-6187, 41-6188, 41-6189
8400724410	41-6190, 41-6194, 41-6191, 41-6193, 41-6196, 41-6197
8400724407	41-6192, 41-6198, 41-6200, 41-6195, 41-6199, 41-6201
8400724403	4987, 4988, 4989, 4993, 4995, 4997

Inspector Name	Date

400BBL TANK

QC Documentation

Manufactured By:



For




Started: Rolls	Completed: Rolls	Started Saddle	Completed Saddle
Nov. 4 th / 6:30 am	Nov. 4 th / 6:30 pm	Nov. 7 th / 11:00	Nov. 8 th / 12:45
Started Subarc	Completed Subarc	Started QC	Completed QC
Nov. 5 th / 8:30 am	Nov. 6 th / 12:00 pm	12:45 pm	Nov. 8, 2013 / 2:15 pm

	400 BBL Inspection Sheet		Effective Date	Procedure ID
	Job # WO-820	Serial #	April 2012	QF-19B
	Customer: Husky		Page 1 of 2	Revision 0 Controlled

Inspection Criteria	P	F	R	Inspection Criteria	P	F	R
Long skid	✓			Legs fit & welded	✓		
Back skid	✓			Back skid to bottom shell	✓		
Saddles	✓			Fitting orientation	✓		
Pull pipes	✓			Manway	✓		
Shells Inner Cross Welds	✓			Flanges two holed	✓		
Shell to Shell Inner Circumference Welds	✓			Couplings	✓		
1 st Course	✓			Serial # bracket	✓		
2 nd Course	✓			Thief hatch	✓		
3 rd Course	✓			Envirovault install & weld	✓		
Roof butt welds	✓			Level indicator couplings, tabs, & half chain links	✓		
Roof Circ weld	✓			Lanyard tabs	✓		
Shell to shell outer circ weld	✓			Back weld all fittings & pups	✓		
1 st Course	✓			Internal piping rounded	✓		
2 nd Course	✓			HP serial number welded on skid	✓		
3 rd Course	✓			Company number welded on skid	~1/2	✓	
Outer cross welds 1 st , 2 nd , 3 rd , 4 th	✓			Ladder	✓		
Floor cross	✓			Ladder cage	✓		
Floor circ inner	✓			Pivot tongue	✓		
Floor circ outer	✓						
Tank centered on skid	✓						
Saddles stitch welded	✓						


Notes

Crack Prohibition	Weld/Base-Metal Fusion	Crater Cross Section	Weld Profiles
None	Thorough fusion	Filled to Size	See Below
Time of Inspection	Undersized Welds	Undercut	Porosity
Within 48 Hours	Undersize portion of the weld shall not exceed 10% of the weld length.	For material less than 1 inch thick, undercut shall not exceed 1/32 inch. For material equal to or greater than 1 in. thick, undercut shall not exceed 1/16 inch for any length of weld.	None allowed



(A) DESIRABLE FILLET WELD PROFILES (B) ACCEPTABLE FILLET WELD PROFILES
Note 1. Convexity, C, of a weld or individual surface bead with dimension W shall not exceed the value of the following table:

WIDTH OF WELD FACE OR INDIVIDUAL SURFACE BEAD, W	MAX CONVEXITY, C
W ≤ 5/16 in. [8 mm]	1/16 in. [2 mm]
W > 5/16 in. [8 mm] TO W < 1 in. [25 mm]	1/8 in. [3 mm]
W ≥ 1 in. [25 mm]	3/16 in. [5 mm]



Inspector Name	Date	Invoice #	Date
Mack Forkhouser	Nov. 9, 2013		

	400 BBL Floor to Shell Inner Weld Dye Pen Inspection		Effective Date	Procedure ID
	Job # W-820	Ser. #	January 2013	QF-29B
	Customer: Husky		Page 1 of 1	Revision 0 Controlled

Procedure

Prior to welding outer weld at the floor joint clean all welds with SKL-5 NDE Testing Material. Apply SKL-SP2 Penetrant on inner weld joint, allow penetrant to set for 15 minutes. Apply SKD-S2, a developer, to gap between the shell and the bottom to outer allow minimum dwell time of one hour, detect all leaks.

Floor to Shell Dye Pen Test Times and Results	# of leaks 0
<u>Start Time:</u> Nov 4 th 4:30	
<u>Stop Time:</u> Nov 4 th 5:30	
<u>Total time:</u> 1hr	

Repair Procedure

Leaks to be repaired per:

1. Grind out the weld at the leak location, 1 inch on each side of the leak.
2. Weld the gouge to complete the weld seam.
3. Clean up the weld.
4. Repeat procedure for all leaks.
5. Attach any and all Dye Pen inspection forms for this floor to shell together and include in tank packet

Date	Inspector Name
Nov 4 2013	Dustin Wales

	400 BBL Pressure Test Report		Effective Date	Procedure ID
	Job # WO-820	Serial # through	April 2012	QF-20B
	Customer: Husky		Page 1 of 1	Revision 0 Controlled

Pressure Gauge # used for testing	2
-----------------------------------	---

Pressure Test

1. Plug all fittings using mechanical pipe plugs
2. Bolt man-way using gaskets and all nuts and bolts
3. Install pressure gauge on bottom drain coupling
4. Hook air-line through the 4" bottom fitting
5. Fill tank with 2 to 2.5 psi.
6. Soap all fittings, weld seams, man-ways and corners
7. Inspect for leaks and mark the same the soap stone
8. De-Pressure tank.

Initial	QC		Weld Location	No. of Leaks	Repair
BM		1	4" RFSO #1	0	
BM		2	4" RFSO #2	0	
BM		3	4" RFSO #3	0	
BM		4	4" RFSO #4	0	
BM		5	4" RFSO #5	0	
BM		6	3" RFSO #1	0	
BM		8	3" RFSO #2	0	
BM		9	4" Downcomer	N/A	
BM		10	Manway	1	Wah
BM		11	Envirovault	7	Wah
BM		12	Thief Hatch	0	
BM		13	Level Indicator	1	Wah
BM		14	Couplings	0	
BM		15	Roof circumference	0	
BM		16	Roof seam	0	
BM		17	Tank body	0	
BM		18	Floor circumference	0	
BM		19	Repads	0	

Leak Repair Procedure

1. Grind out the weld at the leak location, 1 inch on each side of the leak.
2. Weld the gouge to complete the weld seam.
3. Clean up the weld.
4. Repeat procedure for all leaks.
5. Repeat the Pressure Test.

Inspector Name – Initial Inspection	Date	Inspector Name – Re-Inspection
Justin Wales	Nov , 2013	Buddy Mameli

	400BBL Sand Blast Profile	Effective Date	Procedure ID
		Page	Revision

Job #	Serial #	Customer
820		Husky

Blast Profile


Internal

Required: White SP5 2-3 mil


External

Required: Brink SP7


Root




1




S.Lv




2



Stem



3



Q.C. Inspector Signature: _____

Date: 15 Nov. 2013

	400BBL Sand Blast QC Checklist	Effective Date	Procedure ID
		Page	Revision

Job #	Serial #	Customer
820		Husky

This checklist must be filled out prior to moving tank from 'Blast bay' to 'Paint Bay'

Exterior: Brush blast SP7

- ☒ Roof blast
- ☒ Floor blast
- ☒ Back skid, tank apron and tapers blast
- ☒ Bottom skid, saddles, legs, and tank belly blast
- ☒ Left side blast
- ☒ Right side blast
- ☒ Flanges
- ☒ Manway
- ☒ Ladder
- ☒ Textile strips used to check blast profile

Interior: White blast SP5

- ☒ Roof blast
- ☒ Floor blast
- ☒ Left side blast
- ☒ Right side blast
- ☒ Necks
- ☒ Manway flange

Q.C. Inspector Signature: 
Date: 15 Nov. 2013

Update: March 6, 2013 RH

	Highland Coating Procedures	Effective Date	Procedure ID
	Forced Heat Curing Procedure	November 1, 2013	HCP.6
	CONTROLLED	Page 1 of 1	Revision 0

Job #	Serial #	Customer
WO-820		Husky

1. Upon completion of gas-off time, prepare for forced heating.
2. Move tank outside if required.
3. Install heat ducts to thief hatch opening.
4. Turn on *frost fighter*.

NOTE: Manway door is to have ¼" gap during forced cure time. Flange protectors to be installed with ¼" gap.

Must refer to coating specifications for required heating time based on temperature attained.

Tank Cure Times	
Start:	4:00 pm
Stop:	9:00 am
Total:	17

Temperature Attained:	135°
-----------------------	------

Date	Inspector
Nov 14/13	Steven Brown

	400BBL Paint QC	Effective Date	Procedure ID
		Page	Revision

Job #	Serial #	Customer
820		Husky

Description: Internally lined and externally insulated and sealed.

Who/where was it painted: Company: Highland / Sandre
Painter: Doug Cassidy

Type of paint, primer: Internal - Devchem 253
External - Elastospray Sealer - Towerthon

Final DFT: Internal: defects failed 18
External: defects failed 18
Insulation: 1.5 inch average

Any runs, sags, sand in paint, light spots, or any other problems: If Yes describe where, and how severe.

Comments: Aspised & Repaired

Q.C. Inspector Signature: [Signature]
Date: 15 Nov 2013

	Rigging QC Checklist	Effective Date	Procedure ID
		April 2012	QF-22B
	400BBL Tanks	Page 1 of 1	Revision 0 Controlled

Job #	Serial #	Customer
WO-820		Husky

S/N	Task	Inspected By
1	Manway – gasket installed and all bolts tight.	
2	Thief Hatch – sweet service (proper orientation)	
3	Guided Float – SS cable and clamps	
4	Gauge board and decal – (orientation)	
6	Pointer – cable tight and tied off, double clamp tight, proper orientation	
7	Name Plate – check serial # to tank	
8	Cata-dyne Heater – electrical cord installed	
9	N8 truck out pipe installed	
10	Ladder and cage (shipped separately)	
11	4" pipe plug installed and secure	
12	3" pipe plug installed and secure	
13	Complete final walk around	

Comments: _____

Inspector Name	Date
DALE BEAT	15 NOV 2013

