



INSPECTION AND TEST REPORT



www.kingsenergy.com
1-866-660-KING

Owner:	RJV GAS FIELD	AFE:		Date:	10/23/2014	Job:	67324
Instructions:	<input type="checkbox"/> Rental <input type="checkbox"/> Quote <input type="checkbox"/> Pretest <input type="checkbox"/> Repair <input type="checkbox"/> Test Only <input checked="" type="checkbox"/> New <input checked="" type="checkbox"/> Reset <input type="checkbox"/> B.E.R <input type="checkbox"/> VR Update						
L.S.D.:		Loc:		Plant/Area:	VEGREVILLE	Unit/Vessel:	

Valve Data:	-	Seal:	Intact	Style:	Threaded	Inlet:	MNPT	Outlet:	FNPT
		Seal ID:	T	Bonnet:	Closed	Inlet Size:	1.00 inches	Outlet Size:	1.00 inches
Make:	Taylor	NamePlate:	Original	Cap:	Closed	Inlet Rating:	Threaded	Outlet Rating:	Threaded
CRN:	0G01316.2C	Service:	Gas	Orifice:	E	Capacity:	5180 SCFM	Cold Diff Set	1440 psig
Asset No:	94308	Product:	Gas	Orifice Area:	0.212 sq in.	Code Stmp:	NB/UV	Set Press:	1440 psig
Data Plate:	82E8351311	Serial No:	035315-318	Replacing:					

Pilot Data:		Model:		Serial No:	
-------------	--	--------	--	------------	--

Pretest Data:	Test1:	Test2:	Test3:	Units:	Notes1:	Pretest By:
Pressures:	0	0	0		Notes2:	

Disassembly:	-	Height:		Upper BDR:		Lower DBR:		Dis By:	Corey Eye
--------------	---	---------	--	------------	--	------------	--	---------	-----------

Inspection:	-	Replaced:	N	Converted:	Y	Inspected By:	Corey Eye
Seat Matl:	Viton(FKM) 90 d	Bonnet Matl:	N/A	Sizing Basis:	Blocked Flow	Inlet Condition:	Clean
Body Matl:	Carbon Steel	Bellows Matl:	N/A	Spring No:	05-001515	Outlet Cond:	Clean

Part No \ Desc:	Bin Loc:	Condition 1	Condition 2	Recommendation	Work Done	CD Actual
-----------------	----------	-------------	-------------	----------------	-----------	-----------

Assembly:	-	Converted From:		Converted To:		Assembled By:	Corey Eye
-----------	---	-----------------	--	---------------	--	---------------	-----------

Final Test:	-	Set Press:	1440 psig	Gauge 1:	DG5-1	Vacuum Set:		-	-
	-	Back Press:	0	Gauge 2:	6A	Leakage Vac:		Test Date:	10/23/2014
Media:	Air	Temp:	60 °F	BLD %:		Vacuum Act:		Tested By:	Corey Eye
Method:	Bench	Corr Factor:	1	Mens Lift:		-	-	Witness:	
Simmer:		Cold Diff Set:	1440 psig	Leakage:	0 BPM	Set Press Def:	POP	-	-
Re-Seal:		Act Test Press:	1440 psig	-	-	-	-	-	-

Final Insp:	Tag:	Painted:	Pallet:	Sealed:	End Protect.	Flex Gasket:	Inspector:	Corey Eye
-	Yes	Yes	No	Yes	Yes	No	Sign Off:	Russ Spencer

Reset Comments:	RESET VALVE TO 1440 PSI
Inspection Comments:	Previous Reset Values: Set Pressure: 1400 psig ; Capacity: 5037 SCFM ; DataPlate Model: 82E8351311-1400
Final Test Comments:	
Sign Off Comments:	