

| | | | | LSD: | 10-34-0 | 51-04W4 | ļ <u></u> | Date: | 201 | 7-09-08 | SAP Eq | <u>uip</u> r | nent ID | 62066381 | | |
|--------------------------------------------------------------------------------------------------------------------------------|-----------------|------|------------|--------|----------|---------|-------------|----------------|-----------|-------------|----------|--------------|--------------|----------|-----------|-------|
| | | | | | | V | ESSEL ST | ATIC D | ATA | | | | | | | |
| Plant: | | Morg | jan | | | | 0 | P Unit: | | | | s | ystem: | | | |
| Prov. Insp . #: | | | | | NB#: | I/S | С | RN: | N/ | S | | E | quip Tag#: | 62 | 2066381 | |
| Equipment De | scription | : | FLARE I | KNOCKO | UT | | | | | | | s | erial #: | F- | 1018 | |
| Manufacturer: | | FLO- | SKID | | | | | | | | | V | essel Class: | Ve | essel | |
| Internal Acces | is: | No | | | | Descri | ption: | | | | | Y | ear Built: | 1 | 985 | |
| MAWP: | | 103 | | kpa | | At Ten | np | | 66 | С | | N | 1DMT: | | | С |
| Code: | | N/S | | | | RT: | RT1 | | | | | P | WHT: | No |) | |
| Diameter: 6 | 10 | mm | Length | : 304 | 8 mm | (T/T): | mm | OAL: | | mm | | C | rientation: | He | orizontal | |
| SHE | LL | М | lat'l: Unk | nown | | Thickr | ness: | 0 | .00 | mm | | 0 | orr Allowand | e: | 0.00 | mm |
| Nozzle Mat'l: | | | | | | Thickr | ness: | | | | | Ī | orr Allowand | e: | | |
| Internal Coati | ng: | | | | | Intern | al Clad: | | | | | 7 | Capacity: | | 1 | n3 |
| Manway: | | No | | | | Inspe | ction Port: | | No | | | s | kirt | Legs | Sadd | le X |
| Nozzle Rating: 150 lb ANSI Painted: Yes | | | | | | | | I | nsulated: | Yes | | | | | | |
| | | | | | | | PROCES | S DATA | | | | | | | | |
| Production De | scription | | | | | Sweet | | Sou | ır: | Yes | | | | | | |
| Operating Pre | ssure | | | kpa | | Opera | ting Temp: | | | С | | Stat | us: Ope | ating | | |
| | PSV STATIC DATA | | | | | | | | | | | | | | | |
| | | | | | Size(mm) | | Set Press | Capaci | - 1 | Manufacture | `r | | | Last | 50 | rvice |
| Tag # | Serial N | о. | Location | Inle | | Outlet | (kPa) | Imper (SCFN | | Manufacture | ai | | Model | Service | | npany |
| | | | | 0.0 | 0 | 0.00 | 0 | | | | | | | | | |
| PSV DETAILS | | | | | | | | | | | | | | | | |
| | | | Type(Th | read/F | lange) | | AN | SI Rating | 9 | | | | Size | (In/mm) | | |
| PRD Inle | t | | | | | | | | | | | | 0.0 | 0 | | |
| PRD Outl | | | | | | | | | | | | 0.00 | | | | |
| | | | | | | NDE E | quipment | Record | is | | | | | | | |
| Proced | ure # | | Descrip | tion | | Manufac | cturer | | Mod | el# | | 5 | Serial# | | Due Da | ite |
| **** See As | sociated | NDE | <u>-</u> | | | | | | | | <u> </u> | | | <u> </u> | | |
| ***** See Associated NDE Report INSPECTION SUMMARY VESSEL IS ATMOSPHERIC VENTING DIRECTLY INTO FLARE STACK, NO PSV REQUIRED. | | | | | | | | | | | | | | | | |
| RECOMMENDATIONS | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | NC | NCON | FORMANO | ES/INS | SPEC | TION DEF | CIENC | ES | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |



Assessed Next Inspection Date

2022

PRESSURE VESSEL & COLUMN INSPECTION REPORT

| | | INSPECTION PLA | ANNING | | | | | | |
|------------------------------------------------------------------|-------------------|----------------------------------------------------------------------|----------------------|------------------|---------------|------|------------|------------|--|
| Inspection Strategy | | Availability | | Insp | ection Interv | al | 5 year | | |
| Inspection Date | 2017/09/08 | Date of Last Inspect | Date of Last Inspect | | | | 2022/09/08 | | |
| | | REPORT CERTIFI | CATION | | | | | | |
| The SignatureS below certifications specified equipment is consi | , , , | ve been completed in accordance with the he date of next inspection. | e identified insp | pection strategy | and that the | ; | | | |
| Inspected by | Justin Orichowski | | AB Cert # | 000758 | SK PEI # | 214 | Date | 2017/09/08 | |
| Reviewed and Approved by | | | | _ | | Date | | | |
| Criticality Assessment Rerur | lerun | | | | | | | | |



DETAILED INSPECTION VISUAL EXTERNAL

| V1 General Other (Please Explain) Accept No NO ISSUES OBSERVED. V2 General Corrosion Accept No NO CORROSION OBSERVED V3 General Leaks Accept No NO LEAKAGE OBSERVED. V4 Vibration Accept No NO VIBRATION OBSERVED. | IN UT PORTS. |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| V3 General Leaks Accept No NO LEAKAGE OBSERVED. | IN UT PORTS. |
| | |
| V4 Vibration Accept No NO VIBRATION OBSERVED. | |
| | |
| V5 Dissimilar Flange Rating N/A No | |
| V6 Ladder/Stairway N/A No | |
| V7 Heads Accept No HEADS ARE UNDER INSULAT | TION. |
| V8 Guy Wires N/A No | |
| V9 Electrical Ground Accept No VESSEL IS GROUNDED. | |
| V10 Painted Inactive Corrosion N/A No | |
| V11 Coating/Painting Accept No PAINT VIEWED THROUGH U | T PORTS IS IN GOOD CONDITION. |
| V12 Expansion Joint or Bellows N/A No | |
| V13 Gauge/Site Glass Accept No LIQUID LEVEL IS IN GOOD G | CONDITION. |
| V14 Shell Accept No SHELL VIEWED THROUGH U | T PORTS IS IN GOOD CONDITION. |
| V15 Jacket N/A No | |
| V21 Support Other (Please explain) N/A No | |
| V22 Foundation Accept No GROUND NO ISSUES OBSER | VED |
| V23 Anchor Bolts N/A No | |
| V24 Saddle/Skirt Accept No SADDLE | |
| V25 Davit N/A No | |
| V26 Fireproofing N/A No | |
| V31 Connections Other (Please explain) N/A No | |
| V32 Small Branches N/A No | |
| V33 Nozzles N/A No | |
| V34 Manways N/A No | |
| V35 Reinforcing Pads N/A No | |
| V36 Inadequate Thread Engagement N/A No | |
| V37 Bolting Accept No UNDER INSULATION, NO ISS | SUES OBSERVED. |
| V38 Flanges Accept No UNDER INSULATION, NO ISS | SUES OBSERVED. |
| V39 Leak Clamps N/A No | |
| V41 Insulation Other (Please explain) N/A No | |
| V42 Damage Accept No MINOR DENTING ON NORTH | HEAD INSULATION. |
| V43 Penetrations Accept No NO ISSUES OBSERVED. | |
| V44 Insulation Jacket N/A No | |
| V45 Banding Accept No BAND IS TIGHT AND SECUR | E |
| V46 Seals/Joints Accept No JOINTS ARE SEALED. | |
| V51 Relief Devices Other (Please explain) Accept No VESSEL IS ATMOSPHERIC VI PSV REQUIRED. | ENTING DIRECTLY INTO FLARE STACK NO |
| V52 Corrosion N/A No | |
| V53 Leaks N/A No | |
| V54 Restricted Inlet/Outlet N/A No | |



| | LSD: | 10-34-05 | 1-04W4 D a | ate: 201 | L7-09-08 | SAP Equipment ID | 62066381 | |
|-----|------------------------|----------|-------------------|-----------------|----------|------------------|----------|--|
| V55 | Manual Operation Lever | N/A | | | No | | | |

DETAILED INSPECTION OTHER TECHNIQUES

| ID | Location | Observation/Measurement | Acceptance Criteria | NCR | Comments |
|----|----------|-------------------------|---------------------|-----|----------|
| | | | | | |

DETAILED INSPECTION UT THICKNESS

| CML | Nom. Thickness (mm) | CURRENT READINGS (mm) | short term corr rate (mm/y) | long term corr rate (mm/y) | remaining life (year) | Survey Date | Comments |
|------------|---------------------------|-----------------------------|-----------------------------------|----------------------------------|--------------------------|-------------|-------------|
| 05 (SHELL) | 0.00 | 6.78 | 0.0000 | 0.0000 | 198.0 | 2017/09/08 | NO COMMENTS |

| | 10 | (90L 8 STD) | 8.18 | 7.26 | 0.0279 | 0.0279 | 257.3 | 2017/09/08 | NO COMMENTS |
|---|----|-------------|-------|-------|--------|--------|-------|------------|-------------|
| | 15 | (90L 6 STD) | 7.11 | 6.86 | 0.0078 | 0.0078 | 876.2 | 2017/09/08 | NO COMMENTS |
| ſ | 20 | (BAND 6 XS) | 10.97 | 10.52 | 0.0140 | 0.0140 | 748.8 | 2017/09/08 | NO COMMENTS |

| Inspected By | Signature | CGSB Level | CGSB No. | Survey Date | UT Equip | Due Date OF Calibration | NDE Procedure No. |
|----------------------|-----------|------------|----------|-------------|---------------------|----------------------------|----------------------|
| Justin Orichowski | 10-0- | SNT LV 2 | 16325 | 09/08/2017 | 104_91638503_EPOCH4 | 04/30/2018 | WQS UT-001 |





Client:

HUSKY ENERGY

EXAMINATION ILLUSTRATION

| DISTRICT: | ALBERTA NORTH | FACILITY: | MORGAN | LOCATION/LSD: | 10-34-051-04W4 |
|-------------|----------------|------------|----------|---------------------|----------------|
| EQUIP NAME: | FLARE KNOCKOUT | | | PROV REG No.: | |
| SERIAL No.: | F.1018 | Equip No.: | 62066381 | National Board No.: | |



| notes: | | | |
|--------|--|--|--|
| | | | |
| 1 | | | |



Client:

HUSKY ENERGY

PHOTOGRAPHS

| EQUIP NAME: | FLARE KNOCKOUT | | | PROV REG No.: | |
|-------------|----------------|------------|----------|---------------------|--|
| SERIAL No.: | F.1018 | Equip No.: | 62066381 | National Board No.: | |





NAMEPLATE



OVERALL



OVERALL





DAMAGED INSULATION