



CONNECTION SCHEDULE			
WK	SIZE	RATING	SERVICE
A	2"	150# RF	FEED WATER
B	3"	150# RF	SOFT WATER OUTLET
C	2"	150# RF	DRAIN/BACKWASH DISCHARGE
D	1"	NPT	BRINE PUMP BACKWASH INLET
E	1"	NPT	FRESH WATER INLET
F	1"	NPT	BRINE TANK DRAIN

- GENERAL NOTES:
1. ALL PIPING TO BE INTERNALLY & EXTERNALLY GALVANIZED
  2. EXCEPT BRINE LINES.
  3. BRINE LINES TO BE STAINLESS STEEL PIPING.
  4. ALL INSTRUMENT LINES TO BE 1/4" Ø SS. TUBING.

<div>DESIGN AND OPERATING DATA</div>	
EACH PRIMARY	EACH POLISHER
DESIGN PRESSURE: _____	DESIGN PRESSURE: _____
DESIGN FLOW RATE: _____	DESIGN FLOW RATE: _____
RESIN VOLUME: _____	RESIN VOLUME: _____
RESIN BED DEPTH: _____	RESIN BED DEPTH: _____
FREE BOARD: _____	FREE BOARD: _____
VESSEL HEIGHT (SEAM/SEAM): _____	VESSEL HEIGHT (SEAM/SEAM): _____
BRIKE RATE (DILUTED): _____	BRIKE RATE (DILUTED): _____
BACKWASH RATE: _____	BACKWASH RATE: _____
FAST RINSE RATE: _____	FAST RINSE RATE: _____
AIR VENT: _____	AIR VENT: _____
MINIMUM RESIN CAPACITY	MINIMUM RESIN CAPACITY
REQUIRED: _____	REQUIRED: _____
MINIMUM SALT REQUIRED: _____	MINIMUM SALT REQUIRED: _____
DESIGN BRINE DILUTION: _____	DESIGN BRINE DILUTION: _____
VESSEL DIAMETER: _____	VESSEL DIAMETER: _____
APPROXIMATE SHIPPING WEIGHT	APPROXIMATE SHIPPING WEIGHT