

EQ# 66117428

# Certificate of Inspection Permit

**HUSKY OIL OPERATIONS LTD**  
BOX 6525 STN D  
CALGARY/WESTERN CDA UPSTREAM  
ATTN: RON CHAPMAN  
CALGARY, AB  
T2P 3G7

PREFERRED RE-INSP. INTERVAL: 1.00 Yr.

YEAR BUILT: 2006

CRN: R4387.2

SERIAL #: V-4860-001

VOLUME: 0.263 M3

HEATING SURFACE:

SURFACE AREA:

COMPANY CODE:

DESCRIPTION: VERTICAL SEPARATOR

LOCATION: LSD 40-27-57-02-W5M- 100/67-33-063-06W6

MANUFACTURER: IPS MANUFACTURING LIMITED

FH-BC

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	10204 KPA	38 C	-29 C	SV1			TO BE INSTALLED

## OWNER INSTRUCTIONS/REMARKS:

Contact the ABSA Safety Codes Officer before placing the vessel/boiler in service.

Vessel/Boiler to be installed in accordance with the Safety Codes Act and Regulations.

Verify that vessel/boiler is protected by an acceptable ASME Code pressure relief device, of adequate capacity, set at no more than maximum pressure authorized and installed in accordance with the Safety Codes Act & Regulations.

Safety Codes Officer: LICHTENWALD, LARRY

Signature: 

## NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.