

66066151 QPSEPAR 2714
ACTION REPORT N# 601468

**PRESSURE VESSEL INSPECTION REPORT**

FACILITY	Simons Lake	DATE	February 5, 2002	REPORT #	02/02/05-J.A.A.-CC
Prov. Insp. #	405848	CRN	H3897.2	Equip Tag #	

INSPECTION OBSERVATIONS**NONCOMPLIANCES OR INSPECTION DEFICIENCIES ISSUED****EXTERNAL VISUAL INSPECTION**

Vessel has no pressure gauge.

Vessel shell not painted behind the nameplate bracket with rust coloured runs down vessel shell.

Surface corrosion & scaling noted throughout the vessel with shallow pitting noted under scale locations.

Corrosion noted on vessel & piping valves.

EXTERNAL NDE EXAMINATION

UT thickness survey carried out.

INTERNAL VISUAL INSPECTION**INTERNAL NDE EXAMINATION****PRESSURE TEST**

Test Completed	☐ Yes ☐ No	Test Acceptable	☐ Yes ☐ No	Test Report #
----------------	--	-----------------	--	---------------

INSPECTOR CERTIFICATION

I, the undersigned certify that the above equipment has been inspected in accordance with the assigned task list and that statements within this report are correct and represent inspection findings

Inspectors Name J. André Arseneau

Inspector's Signature

Inspection Company Alliance Engineering and Inspection

Date February 5, 2002

LEAD INSPECTOR'S ACCEPTANCE & SCHEDULE CONFIRMATION

Lead Inspector

Signature

Date

Vessel Inspection Interval 5 Years

Leave "as-is" ☐

Change to

PSV Inspection Interval 5 Years

Leave "as-is" ☐

Change to

Office Use Only Report Entered to SEQA Database by
Static Data Verified by

Date
Date